

# TEXAS DEPARTMENT OF INSURANCE

Engineering Services Program / MC 103-3A 333 Guadalupe Street P.O. Box 149104 Austin, Texas 78714-9104  
Phone No. (512) 322-2212 Fax No. (512) 463-6693

**PRODUCT EVALUATION**  
DR-197

Effective Date: February 1, 2014  
Reevaluation Date: **July 2016**

The following product has been evaluated for compliance with the wind loads specified in the **International Residential Code (IRC)** and the **International Building Code (IBC)**.

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code and the Texas Engineering Practice Act.

**Designer Series SmartSash II Aluminum Clad Wood Sliding Glass Door, OXO, Type III, Non-impact Resistant**, manufactured by

**Pella Corporation**  
102 Main Street  
Pella, Iowa 50219  
Telephone: (641) 621-1000

## General Description:

System	Description	Label Rating	Design Pressure Rating
1	Designer Series SmartSash II Aluminum Clad Wood Sliding Glass Doors Type III; (OXO)	LC-PG40 3658x2426 – Type SD	± 40 psf

## Product Dimensions:

System	Overall Size	Fixed/Operable Panel Size
1	144.00" x 95.50"	Fixed (1): 48.00" x 94.00" Operable (2): 48.00" x 94.00"

## Product Identification (Certification Agency Label on Door):

System		
1	Certification Agency	WDMA
	Manufacturer's Name or Code Name	Pella Corporation
	Product Name	Sliding Contemporary Door (OXO) Fixed/Vent/Fixed
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08; AAMA/WDMA/CSA 101/I.S.2/A440-11

## Impact Resistance:

Impact Resistant	Requirement
No	Impact protective system required when product is installed in areas where windborne debris protection is required

**Installation:** The wood wall framing members shall be minimum Spruce-Pine-Fir dimension lumber. The door is secured to the wall framing using the aluminum nailing flange with minimum 2" long, 11 gauge smooth shank roofing nails. Along the head and side jambs, the fasteners are spaced approximately 4 to 8 inches from each corner and 4 to 8 inches on center. In addition, the frame head is secured to the wall framing with minimum No. 8 x 3" screws spaced approximately 6 inches from each corner and 10 inches on center. The sill is secured with minimum No. 8 x 2 ½" screws located in pre-drilled holes. The fasteners shall be long enough to penetrate a minimum of 1 ½ inches into the wall framing.

**Note:** The manufacturer's installation instructions shall be available on the job site during installation. All fasteners shall be corrosion resistant as specified in the International Residential Code (IRC), the International Building Code (IBC), and the Texas Revisions.