



# Product Evaluation

DR510 | 0914

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

**Evaluation ID:** DR-510

**Effective Date:** February 1, 2012

**Revised Date:** September 1, 2014

**Re-evaluation Date:** April 2015

**Product Name:** Series GA 7630 Vinyl Sliding Patio Doors, Non-Impact Resistant

**Manufacturer:** MI Windows and Doors, LLC.  
650 West Market Street  
Gratz, PA 17030-0370  
(717) 365-3300

### General Description:

System	Description	Label Rating	Design Pressure Rating
1	Series GA 7630 Vinyl Sliding Glass Door (Fin); (XO)	R-PG25 106x80	+25

### Product Dimensions:

System	Overall Size	Operable Panel Size
1	106-3/8" x 79-1/2"	47-1/4" x 77-3/4"

### Product Identification (Certification Agency Label on Door):

System		
1	Certification Agency	AAMA
	Manufacturer's Name or Code Name	MTL-12
	Product Name	Series GA 7630 Sliding Glass Door
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08

**Impact Resistance:**

System	Impact Resistant	Requirement
1	No	Impact protective system required when product is installed in areas where windborne debris protection is required.

**Installation:**

System		
1	Type of Installation	Fin
	Wall Framing	Southern Pine
	Fasteners	Minimum No.6d common nails
	Fastener Location/Spacing	Located 6" from each corner and 17" on center along the perimeter
	Fastener Penetration	Minimum of 1-1/2" into the wall framing members

**Note:** The manufacturer’s installation instructions shall be available on the job site during installation. All fasteners shall be corrosion resistant as specified in the International Residential Code (IRC), the International Building Code (IBC), and the Texas Revisions.