



Product Evaluation

DR602 | 0816

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: DR-602

Effective Date: August 1, 2016

Re-evaluation Date: July 2020

Product Name: 6'-8" and 8'-0" Glazed Fiberglass Non-Impact Resistant Doors, Inswing & Outswing, Singles & Doubles with and without Non-Impact Sidelites

Manufacturer: Therma-Tru Corporation
118 Industrial Drive
Edgerton, OH 43517
(419) 298-1740

General Description:

System	Description	Label Rating	Drawing Number
1	3'-0" x 6'-8" Glazed Fiberglass Single Door Inswing/Outswing (X)	Smooth Star/Fiber Classic Inswing +35/-40 psf Outswing +35/-35 psf Classic Craft Inswing +50/-55 psf Outswing +50/-50 psf	TX-4262 Rev 1
2	3'-0" x 6'-8" Glazed Fiberglass Single Door w/ Sidelite & Combination Reinforced Mullion, Inswing/Outswing; (OX/XO)	Smooth Star/Fiber Classic Inswing +35/-40 psf Outswing +35/-35 psf Classic Craft Inswing +50/-55 psf Outswing +50/-50 psf	TX-4262 Rev 1

General Description (cont.):

System	Description	Label Rating	Drawing Number
3	3'-0" x 6'-8" Glazed Fiberglass Single Door w/ Sidelites & Combination Reinforced Mullion, Inswing/Outswing; (OXO)	Smooth Star/Fiber Classic Inswing +35/-40 psf Outswing +35/-35 psf Classic Craft Inswing +50/-55 psf Outswing +50/-50 psf	TX-4262 Rev 1
4	6'-0" x 6'-8" Glazed Fiberglass Double Door, Inswing/Outswing (XX)	Smooth Star/Fiber Classic Inswing +35/-40 psf Outswing +35/-35 psf Classic Craft Inswing +35/-40 psf Outswing +35/-35 psf	TX-4263 Rev 1
5	6'-0" x 6'-8" Glazed Fiberglass Double Door w/ Sidelites, Inswing/Outswing (OXXO)	Smooth Star/Fiber Classic Inswing +35/-40 psf Outswing +35/-35 psf Classic Craft Inswing +35/-40 psf Outswing +35/-35 psf	TX-4263 Rev 1
6	3'-0" x 8'-0" Glazed Fiberglass Single Door Inswing/Outswing (X)	Smooth Star/Fiber Classic Inswing +30/-35 psf Outswing +30/-30 psf Classic Craft <u>Kwikset Standard Strike</u> Inswing +40/-50 psf Outswing +40/-40 psf <u>Kwikset Security Strike</u> Inswing +47/-50 psf Outswing +47/-47 psf	TX-4264 Rev 1
7	3'-0" x 8'-0" Glazed Fiberglass Single Door w/ Sidelite & Combination Reinforced Mullion, Inswing/Outswing (OX/XO)	Smooth Star/Fiber Classic Inswing +30/-35 psf Outswing +30/-30 psf Classic Craft <u>Kwikset Standard Strike</u> Inswing +40/-50 psf Outswing +40/-40 psf <u>Kwikset Security Strike</u> Inswing +47/-50 psf Outswing +47/-47 psf	TX-4264 Rev 1

General Description (cont.):

System	Description	Label Rating	Drawing Number
8	3'-0" x 8'-0" Glazed Fiberglass Single Door w/ Sidelites & Combination Reinforced Mullion, Inswing/Outswing (OXO)	Smooth Star/Fiber Classic Inswing +30/-35 psf Outswing +30/-30 psf Classic Craft <u>Kwikset Standard Strike</u> Inswing +40/-50 psf Outswing +40/-40 psf <u>Kwikset Security Strike</u> Inswing +47/-50 psf Outswing +47/-47 psf	TX-4264 Rev 1
9	6'-0" x 8'-0" Glazed Fiberglass Double Door, Inswing/Outswing (XX)	Smooth Star/Fiber Classic Inswing +30/-35 psf Outswing +30/-30 psf Classic Craft Inswing +30/-35 psf Outswing +30/-30 psf	TX-4265 Rev 1
10	6'-0" x 8'-0" Glazed Fiberglass Double Door w/ Sidelites, Inswing/Outswing (OXXO)	Smooth Star / Fiber Classic Inswing +30/-35 psf Outswing +30/-30 psf Classic Craft Inswing +30/-35 psf Outswing +30/-30 psf	TX-4265 Rev 1

Dimensions:

System	Overall Size	Door Panel Size	Sidelite Panel Size	Max Daylight Opening size
1	Inswing: 37-3/4" x 82-1/8" Outswing: 37-3/4" x 81-3/16"	36" x 79-1/4"	NA	Refer to Therma-Tru Corporation Drawings : TX-4262 Rev-1, TX-4263 Rev-1, TX-4264 Rev-1, TX-4265 Rev-1, dated 10/08/2012, signed and sealed by Lyndon F. Schmidt, P.E. on 7/22/2015.
2	Inswing: 54-3/4" x 82-1/8" Outswing: 54-3/4" x 81-3/16"	36" x 79-1/4"	14" x 79-1/4"	
3	Inswing: 71-3/4" x 82-1/8" Outswing: 71-3/4" x 81-3/16"	36" x 79-1/4"	14" x 79-1/4"	
4	Inswing: 74-5/8" x 82-1/8" Outswing: 74-5/8" x 81-3/16"	36" x 79-1/4"	NA	
5	Inswing: 105-5/8" x 82-1/8" Outswing: 105-5/8" x 81-3/16"	36" x 79-1/4"	14" x 79-1/4"	

Dimensions (cont.):

System	Overall Size	Door Panel Size	Sidelite Panel Size	Max Daylight Opening size
6	Inswing: 37-3/4" x 98-1/8" Outswing: 37-3/4" x 97-3/16"	36" x 95-1/4"	NA	Refer to Therma-Tru Corporation Drawings : TX-4262 Rev-1, TX-4263 Rev-1, TX-4264 Rev-1, TX-4265 Rev-1, dated 10/08/2012, signed and sealed by Lyndon F. Schmidt, P.E. on 7/22/2015.
7	Inswing: 54-3/4" x 98-1/8" Outswing: 54-3/4" x 97-3/16"	36" x 95-1/4"	14" x 95-1/4"	
8	Inswing: 71-3/4" x 98-1/8" Outswing: 71-3/4" x 97-3/16"	36" x 95-1/4"	14" x 95-1/4"	
9	Inswing: 74-5/8" x 98-1/8" Outswing: 74-5/8" x 97-3/16"	36" x 95-1/4"	NA	
10	Inswing: 105-5/8" x 98-1/8" Outswing: 105-5/8" x 97-3/16"	36" x 95-1/4"	14" x 95-1/4"	

Hardware Description and Installation:

System	Component	Quantity	Attachment Method
1-5	4" Butt Hinges	3	For proper installation of hardware and components refer to Therma-Tru drawings TX-4262 Rev 1 & TX-4263 Rev 1, dated 10/08/2012, signed & sealed by Lyndon F. Schmidt, P.E. on 7/22/2015.
	Lock and deadbolt strike plate	1 per lockset & deadbolt	
	Kwikset Signature Series or Schlage "F" Series lockset	1	
	Kwikset Signature Series (980) or Schlage "B" Series deadbolt	1	
6-8	4" Butt Hinges	4	For proper installation of hardware and components refer to Therma-Tru drawings TX-4264 Rev 1, dated 10/08/2012, signed & sealed by Lyndon F. Schmidt, P.E. on 7/22/ 2015.
	Lock and deadbolt strike plate	1 per lockset & deadbolt	
	Kwikset Signature Series	1	
	Kwikset Signature Series (980)	1	
9-10	4" Butt Hinges	4	For proper installation of hardware and components refer to Therma-Tru drawings TX-4265 Rev 1, dated 10/08/2012, signed & sealed by Lyndon F. Schmidt, P.E. on 7/22/2015.
	Lock and deadbolt strike plate	1 per lockset & deadbolt	
	Kwikset Signature Series or Schlage "F" Series lockset	1	
	Kwikset Signature Series (980) or Schlage "B" Series deadbolt	1	

Product Identification (Manufacturer label on door):

System		
1	Certification Agency	Self-labeled by manufacturer
	Manufacturer's Name or Code Name	Therma-Tru Corporation, Edgerton, OH
	Product Name	Glazed Fiberglass Single Door (Smooth Star, Fiber Classic and Classic Craft)
	Test Standards	ASTM E330-02
2	Certification Agency	Self-labeled by manufacturer
	Manufacturer's Name or Code Name	Therma-Tru Corporation, Edgerton, OH
	Product Name	Glazed Fiberglass Single Door w/ Sidelite & Combination Reinforced Mullion (Smooth Star, Fiber Classic and Classic Craft)
	Test Standards	ASTM E330-02
3	Certification Agency	Self-labeled by manufacturer
	Manufacturer's Name or Code Name	Therma-Tru Corporation, Edgerton, OH
	Product Name	Glazed Fiberglass Single Door w/ Sidelites & Combination Reinforced Mullion (Smooth Star, Fiber Classic and Classic Craft)
	Test Standards	ASTM E330-02
4	Certification Agency	Self-labeled by manufacturer
	Manufacturer's Name or Code Name	Therma-Tru Corporation, Edgerton, OH
	Product Name	Glazed Fiberglass Double Door (Smooth Star, Fiber Classic and Classic Craft)
	Test Standards	ASTM E330-02
5	Certification Agency	Self-labeled by manufacturer
	Manufacturer's Name or Code Name	Therma-Tru Corporation, Edgerton, OH
	Product Name	Glazed Fiberglass Double Door w/ Sidelites (Smooth Star, Fiber Classic and Classic Craft)
	Test Standards	ASTM E330-02
6	Certification Agency	Self-labeled by manufacturer
	Manufacturer's Name or Code Name	Therma-Tru Corporation, Edgerton, OH
	Product Name	Glazed Fiberglass Single Door (Smooth Star, Fiber Classic and Classic Craft)
	Test Standards	ASTM E330-02
7	Certification Agency	Self-labeled by manufacturer
	Manufacturer's Name or Code Name	Therma-Tru Corporation, Edgerton, OH
	Product Name	Glazed Fiberglass Single Door w/ Sidelite & Combination Reinforced Mullion (Smooth Star, Fiber Classic and Classic Craft)
	Test Standards	ASTM E330-02

Product Identification (Manufacturer label on door) - Continued:

System		
8	Certification Agency	Self-labeled by manufacturer
	Manufacturer's Name or Code Name	Therma-Tru Corporation, Edgerton, OH
	Product Name	Glazed Fiberglass Single Door w/ Sidelites & Combination Reinforced Mullion (Smooth Star, Fiber Classic and Classic Craft)
	Test Standards	ASTM E330-02
9	Certification Agency	Self-labeled by manufacturer
	Manufacturer's Name or Code Name	Therma-Tru Corporation, Edgerton, OH
	Product Name	Glazed Fiberglass Double Door (Smooth Star, Fiber Classic and Classic Craft)
	Test Standards	ASTM E330-02
10	Certification Agency	Self-labeled by manufacturer
	Manufacturer's Name or Code Name	Therma-Tru Corporation, Edgerton, OH
	Product Name	Glazed Fiberglass Double Door w/ Sidelites, Inswing/Outswing (Smooth Star, Fiber Classic and Classic Craft)
	Test Standards	ASTM E330-02

Impact Resistance:

System	Impact Resistant	Requirement
1-10 Doors and Sidelites	No	Impact protective system required when product is installed in areas where windborne debris protection is required

Acceptance of Smaller Assemblies: Door assemblies with dimensions equal to, or smaller than those specified are acceptable with the limitations specified in this report.

Sidelites: Sidelites must only be used with doors. Sidelites must not be installed individually.

Installation:

System		
1-10	Type of Installation	For proper installation of door and sidelites refer to Therma-Tru Corporation Drawings: TX-4262 Rev-1, TX-4263 Rev-1, TX-4264 Rev-1, TX-4265 Rev-1, and dated 10/08/2012, signed and sealed by Lyndon F. Schmidt, P.E. on 7/22/2015.
	Wall Framing	
	Fasteners	
	Fastener Embedment	
	Fastener Location/Spacing	

Note: Keep the manufacturer's installation instructions on the job site during installation. Use corrosion resistant fasteners as specified in the IRC, the IBC, and the Texas Revisions.