

# TEXAS DEPARTMENT OF INSURANCE

Engineering Services Program / MC 103-3A 333 Guadalupe Street P.O. Box 149104 Austin, Texas 78714-9104  
 Phone No. (512) 322-2212 Fax No. (512) 463-6693

**PRODUCT EVALUATION**  
 DR-649

Effective Date: November 1, 2013  
 Reevaluation Date: **March 2016**

The following product has been evaluated for compliance with the wind loads specified in the **International Residential Code (IRC)** and the **International Building Code (IBC)**.

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code and the Texas Engineering Practice Act.

**Fiberglass Inswing Hinged Glazed Doors with Sidelites, Non-Impact Resistant**, manufactured by

**Nan Ya Plastics Corporation USA / Neuma Doors**  
**8989 North Loop East**  
**Houston, Texas 77029**  
**Telephone: (713) 674-7822**

**General Description:**

System	Description	Label Rating	Design Pressure Rating
1	Fiberglass Inswing Hinged Glazed Doors with Sidelites	R-PG50 144 x 96-SHD	+50/-50 psf
2	Fiberglass Inswing Hinged Glazed Doors with Sidelites	R-PG60 144 x 83-SHD	+60/-60 psf

**Product Dimensions:**

System	Overall Size	Active/Passive Panel Size	Sidelite Panel Size	Glass Daylight Opening Size
1	143.25" x 95.75"	Two: 34.25" x 92.13"	Two: 34.50" x 92.13"	21.00" x 79.00"
2	143.13" x 82.50"	Two: 34.50" x 79.06"	Two: 34.50" x 79.06"	25.00" x 63.00"

**Product Identification (Certification Agency Label on Door):**

System	Certification Agency	NAMI
1	Manufacturer's Name or Code Name	Nan Ya Plastics USA
	Product Name	Inswing Fiberglass Patio Door w/ or w/o Sidelites
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08
	Certification Agency	NAMI
2	Manufacturer's Name or Code Name	Nan Ya Plastics USA
	Product Name	Inswing Fiberglass Double Door w/ or w/o Sidelites
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08
	Certification Agency	NAMI

**Hardware:**

**System 1:**

- Hinges; Four required per door; Secured to the door panel with four No. 10 x 2" screws. Secured to the door jamb with two No. 10 x  $\frac{7}{8}$ " screws and two No. 10 x 2" screws.
- Surface mount 4-point locking system with lever type handle key operator; Located on the active door panel.
- Surface mount 2-point locking system with lever type handle key operator; Located on the inactive panel.
- Strike plate; One required; Located on the inactive panel lockstile; Secured with two No. 10 x  $1\frac{1}{8}$ " screws and two (2) No. 10-32 x  $\frac{5}{16}$ " screws.
- Strike plate; One required; Located on the inactive panel lockstile; Secured with two No. 10 x  $\frac{7}{8}$ " screws.
- Strike plate – head; One required; Located on the door frame head; Secured with two No. 8 x 3" screws.
- Strike plate – sill; One required; Secured to the sill with two No. 8 x 3" screws .

**System 2:**

- Hinges; Three required per door; Secured to the door panel with four No. 10 x 2" screws. Secured to the door jamb with two No. 10 x  $\frac{7}{8}$ " screws and two No. 10 x 2" screws.
- Surface mount 2-point locking system with lever type handle key operator; Located on the active panel.
- Strike plate; One required; Located on the inactive panel lockstile; Secured with two No. 10 x  $1\frac{1}{8}$ " screws.
- Flush mounted manually operated flush bolts; Located on the inactive panel lock stile at the head and sill; Each secured with two (2) No. 10 x 1" screws.
- Strike plate – head; One required; Located on the door frame head; Secured with two No. 8 x 3" screws.
- Strike plate – sill; One required; Secured to the sill with two No. 8 x 3" screws .

**Sill and Threshold:**

- 2.00" high aluminum inswing sill

**Impact Resistance:**

Impact Resistant	Requirement
No	Impact protective system required when product is installed in areas where windborne debris protection is required

**Qualified Configurations:** O / X / OX / XO / OXO / XX / XXO / OXX / OXXO. Sidelites may be installed without doors.

**Installation:**

**Design Drawings:**

**System 1:** The doors shall be installed in accordance with Drawing No. 08-01535, titled "Series Inswing Patio Door w/ and w/o Sidelites," sheets 1 through 8 of 8, dated April 9, 2012, signed and sealed by Luis R. Lomas., P.E on April 11, 2012. The stated drawings will be referred to as the approved drawings in this evaluation report.

**System 2:** The doors shall be installed in accordance with Drawing No. 08-01537, titled "Inswing Entrance Door w/ and w/o Sidelites," sheets 1 through 8 of 8, dated April 16, 2012, signed and sealed by Luis R. Lomas., P.E on April 18, 2012. The stated drawings will be referred to as the approved drawings in this evaluation report.

**Wall Framing Construction:** The doors may be mounted to several types of wall framing construction. The types of wall framing construction allowed include:

- Concrete (minimum compressive strength: 3,200 psi)
- Hollow concrete block; ASTM C-90, Grade N, Type 1 (or greater)
- Wood dimension lumber (minimum Spruce-Pine-Fir)

**Installation:**

- Refer to Sheet 1 of 8 of the approved drawings for the elevation and notes.
- Refer to Sheets 3 of 8 and 4 of 8 of the approved drawings for the anchor layout and notes.
- Refer to Sheets 5 of 8 through 8 of 8 of the approved drawings for installation details.
- The approved drawings indicate the minimum embedment depths for the fasteners and the minimum edge distances (minimum distance fastener must be from the edge of the substrate material) for the fasteners.

**Note:** The manufacturer's installation instructions shall be available on the job site during installation. All fasteners shall be corrosion resistant as specified in the International Residential Code (IRC), the International Building Code (IBC), and the Texas Revisions.