

# TEXAS DEPARTMENT OF INSURANCE

Engineering Services / MC 103-3A 333 Guadalupe Street P.O. Box 149104 Austin, Texas 78714-9104  
Phone No. (512) 322-2212 Fax No. (512) 463-6693

---

## PRODUCT EVALUATION RC-267

Effective November 1, 2010

*The following product has been evaluated for compliance with the wind loads specified in the **International Residential Code (IRC)** and the **International Building Code (IBC)**. This product shall be subject to reevaluation **November 2014**.*

*This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.*

*This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.*

**Versico Versiweld TPO and VersiFlex PVC Roofing Systems** manufactured by

**Versico**  
**P.O. Box 1289**  
**Carlisle, PA 17013**  
**(800) 992-7663**

will be accepted in designated catastrophe zones along the Texas Gulf Coast when installed in accordance with the manufacturer's installation instructions and this product evaluation.

## PRODUCT DESCRIPTION

**Versico Versiweld TPO** roof membranes are nominal 0.045" thick or thicker flexible TPO (thermoplastic olefin) sheets. **Versico VersiFlex PVC** roof membranes are nominal 0.050" thick or thicker flexible PVC (polyvinyl chloride) sheets.

## LIMITATIONS and INSTALLATION

**General Installation Requirements:** All International Residential Code (IRC) and the International Building Code (IBC) requirements must be satisfied and manufacturer's installation instructions followed, unless otherwise specified by this product evaluation.

**For all applications:** The roof shall have a minimum slope of  $\frac{1}{4}$ :12.

### TPO Assembly No. 1

**Design Wind Pressure:** -67.5 psf

**Roof Deck:** The roof deck shall consist of  $\frac{19}{32}$ " or greater plywood.

**Insulation:** A minimum of 1.5" thick polyisocyanurate roof insulation.

The roof insulation is secured with four (4) #12 insulation fasteners and 3" steel plates per every 4' x 8" board.

**Membrane:** One ply of Versico Versiweld TPO membrane, 6'-0" wide sheet.

The membrane is secured to the roof deck with Versico HPV-X fasteners and  $2\frac{3}{8}$ " barbed plates spaced 6" o.c. along the seams of the membrane. The overlapping membrane edge is sealed with a  $1\frac{1}{2}$ " wide heat weld.

### **TPO Assembly No. 2**

**Design Wind Pressure:** -52.5 psf

**Roof Deck:** The roof deck shall consist of  $\frac{19}{32}$ " or greater plywood.

**Insulation:** A minimum of 1.5" thick polyisocyanurate roof insulation.

The roof insulation is secured with four (4) #12 insulation fasteners and 3" steel plates per every 4' x 8" board.

**Membrane:** One ply of Versico Versiweld TPO membrane, 8'-0" wide sheet

The membrane is secured to the roof deck with Versico HPV-X fasteners and  $2\frac{3}{8}$ " barbed plates spaced 6" o.c. at the seams of the membrane. The overlapping membrane edge is sealed with a  $1\frac{1}{2}$ " wide heat weld.

### **PVC Assembly No. 1**

**Design Wind Pressure:** -60 psf

**Roof Deck:** The roof deck shall consist of  $\frac{19}{32}$ " thick or greater plywood.

**Insulation:** A minimum of 1.5" thick polyisocyanurate roof insulation.

The roof insulation is secured with four (4) #12 insulation fasteners and 3" steel plates per every 4' x 8" board.

**Membrane:** One ply of Versico VersiFlex PVC membrane, 81" wide sheet.

The membrane is secured to the roof deck with Versico HPV-X fasteners and  $2\frac{3}{8}$ " barbed plates spaced 6" o.c. along the seams of the membrane. The overlapping membrane edge is sealed with a  $1\frac{1}{2}$ " wide heat weld.

**Note:** The manufacturer's installation instructions shall be on the job site during the installation. All fasteners shall be corrosion resistant as specified in the International Residential Code (IRC) and the International Building Code (IBC) and the Texas Revisions.