

TEXAS DEPARTMENT OF INSURANCE

Engineering Services Program / MC 103-3A 333 Guadalupe Street P.O. Box 149104 Austin, Texas 78714-9104
Phone No. (512) 322-2212 Fax No. (512) 463-6693

PRODUCT EVALUATION RC-361

Effective February 1, 2013

*The following product has been evaluated for compliance with the wind loads specified in the **International Residential Code (IRC)** and the **International Building Code (IBC)**. This product shall be subject to reevaluation **February 2017**.*

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

Sem-Lok 0.032 Standing Seam Aluminum Roof Panels manufactured by

Southeastern Metals Manufacturing Company (SEMCO)
11801 Industry Drive
Jacksonville, Florida 32218
(904) 757-4200

and

Dot Metals
18757 Bracken Drive
San Antonio, TX 78266
(800) 331-9966

is acceptable in designated catastrophe zones along the Texas Gulf Coast when installed in accordance with the manufacturer's installation instructions and this product evaluation.

PRODUCT DESCRIPTION

The Sem-Lok aluminum roof panel is a concealed fastened metal roof panel. The metal roof panels are manufactured from 0.032 aluminum 3105 H-24, and has 16" wide coverage with 1" tall ribs.

LIMITATIONS

Design Wind Pressures: For installations to nominal $\frac{1}{32}$ inch plywood roof decks, design wind pressure limitations are specified in Table 1.

Installation Over an Existing Roof Covering: Installation over an existing roof covering is not covered in this product evaluation report.

Roof Slope: The Sem-Lok aluminum panels shall not be installed on roofs with a roof slope less than 3:12.

Roof Framing Members: The roof framing members shall be spaced a maximum of 24 inches on center.

INSTALLATION INSTRUCTIONS

General Installation Requirements: All International Residential Code (IRC) and the International Building Code (IBC) requirements must be satisfied and manufacturer's installation instructions followed, unless otherwise specified by this product evaluation.

Table 1

Attachment of .032 Sem-Lok Aluminum Panels to minimum $\frac{1}{32}$ inch plywood roof decks

System	Design Wind Pressure (psf)	Attachment to Plywood
1	-63.75	Fasteners spaced 7" o.c.
2	-101	Fasteners spaced 7" o.c.

Underlayment: A minimum of one layer of No. 30 (Type II) asphalt felt shall be used. The underlayment used shall comply with one or more of the following: ASTM D 226, ASTM D 4869, or ASTM D 1970. The felt shall be installed with 6 inch side laps and 3 inch end laps. The felt shall be fastened to the roof deck with corrosion resistant fasteners in accordance with the manufacturer's installation instructions. Fasteners shall be applied along the overlaps not farther apart than 36 inches on center.

Attachment of Panels to Wood Deck: The aluminum roof panels are secured to the roof deck with No. 10-12 x 1" pancake head screws spaced 7" o.c. along the seam. Refer to Figure 1 for detail on the panel profile. The seams are reinforced with an 0.032" aluminum HVHZ cleat CL-3 (42" in length). The CL-3 cleat is installed between adjoining panels along each seam. Refer to Figure 2 for lap detail. For System 2 assemblies, a $\frac{1}{2}$ " wide continuous bead of Liquid Nails Heavy Duty Construction Adhesive is applied top side of the CL-3 cleat along the fastening line adhering the top, overlapping panel at the base of the seam and panel. Refer to Figure 3 for lap detail with adhesive.

Trims, Closures, and Accessories: Components, such as the eave trim, rake trim, ridge trim, hip trim, and valley trim shall be installed as required by the manufacturer.

Panel Ends and End Laps: As required by the manufacturer.

Panel Edges: As required by the manufacturer.

Note: The manufacturer's installation instructions shall be on the job site during the installation. All fasteners shall be corrosion resistant as specified in the International Residential Code (IRC), the International Building Code (IBC), and the Texas Revisions.




Figure 1: .032 Aluminum Sem-Lok Panel




Figure 2: Lap Detail




Figure 3: Lap Detail with Adhesive