



Product Evaluation

RC409 | 0915

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: RC-409

Effective Date: September 1, 2015

Re-evaluation Date: May 2017

Product Name: 26-Gauge 7/8" Corrugated Metal Roof Panels Installed over a Plywood Deck

Manufacturer: Metal Sales Manufacturing Corporation
3838 North General Bruce Drive
Temple, TX 76501-6505
(254) 791 6550

General Description:

The 7/8" Corrugated metal roof panels have 29-1/3" maximum coverage. The metal roof panels have corrugations 7/8" high and spaced 2-2/3" on center. The steel roof panels are manufactured from minimum 26-gauge (0.0171" thick) steel with minimum yield strength of 80 ksi. The panels must have a Galvalume or Galvanized coating that conforms to ASTM A 792 or ASTM A 653 and may be pre-painted.

Limitations:

Roof Framing: The metal roof panels must be installed over a minimum 15/32" thick plywood deck. Thicker wood sheathing may be used; however, the design pressure rating for the metal roof panels will be as specified in this evaluation report.

New Roof Framing Attachment: The roof framing must meet or exceed the uplift requirements of the IRC or IBC and must be installed as required for resistance to wind loads.

Design Wind Pressures: The design pressure uplift load resistance must be as specified in Table 1.

Roof Slope: The metal roofing panels may be installed on roofs with a roof slope as low as 1/2:12 if sealant is used on the side laps. If sealant is not used on the panel side laps, the minimum roof slope is 3:12.

Application of the sealant must be in accordance with the manufacturer's installation instructions and the Metal Sales 7/8" Corrugated Metal Metal Roof Panel Details.

Table 1

Attachment of minimum 26 gauge 7/8" Corrugated Metal Roof Panels to Minimum 15/32" Plywood

Design Wind Pressure (psf)	Attachment of Roof Panel to 15/32" Plywood
-93.5	#10-14 x 2" screws @ 1' on center
-80.4	#10-14 x 2" screws @ 2' on center
-67.4	#10-14 x 2" screws @ 3' on center
-54.3	#10-14 x 2" screws @ 4' on center
-41.2	#10-14 x 2" screws @ 5' on center

Installation Over an Existing Roof Covering: Installation over an existing roof covering is limited to a maximum of one existing layer of composition shingles, wood shingles or shakes, built-up roofing, or roll roofing applied over an existing, solid roof deck of minimum 15/32" plywood. Inspection of the existing roof deck must be made prior to the installation of the roof panels. The condition of the existing roof deck must be acceptable to receive the metal roofing panels before the metal roofing panel installation proceeds. Note: Underlayment is required to be installed. The fasteners must be long enough to penetrate completely through the roof deck.

Installation:

General: The metal roof panels must be installed in accordance with the manufacturer's recommended installation instructions and this evaluation report.

Underlayment: For installations over a solid deck, use a minimum of one layer of No. 30 (Type II) asphalt felt shall be used. The underlayment used must comply with one or more of the following: ASTM D 226, ASTM D 4869, or ASTM D 1970. The underlayment must be installed with 6-inch side laps and 3-inch end laps. The underlayment must be applied with corrosion-resistant roofing nails spaced a maximum of 36" on center along the side laps.

Attachment of Metal Roof Panels to Wood Deck: The metal roof panels must be secured to the wood deck as follows:

Anchorage: The panels must be fastened in the center of the corrugations at 8" on center across the width of the panels and in accordance with Table 1 along the length of the panel with minimum #10-14 x 2" hex head wood screws with 7/16" seal washers to minimum 15/32" plywood roof sheathing. The panel must be fastened along the rake at 6" on center with #10-14 x 2" hex head wood screws with 7/8" diameter seal washers. The panel must be fastened along the ends at the center of the corrugations 8" on center with #10-14 x 2" hex head wood screws with 7/8" seal washers. The fasteners must be long enough to penetrate completely through the roof deck.

Trims, Closures and Accessories: Components, such as eave trim, rake trim, ridge trim, hip trim and valley trim, must be installed as required by the manufacturer and the 7/8" Corrugated Metal Roof Panel Details.

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC, the IBC, and the Texas Revisions.