



# Product Evaluation

WIN1393 | 0615

Engineering Services Program

*The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).*

*This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.*

*This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.*

*For more information, contact TDI Engineering Services Program at (800) 248-6032.*

**Evaluation ID:** WIN-1393

**Effective Date:** June 1, 2015

**Re-evaluation Date:** May 2018

**Product Name:** Architect Series Precision Fit Aluminum Clad Wood Vent Awning Windows, Non-Impact Resistant

**Manufacturer:** Pella Corporation  
102 Main Street  
Pella, IA 50219  
(641) 621-1000

### General Description:

System	Description	Label Rating	Design Pressure Rating
1	Architect Series Precision Fit Wood Vent Awning Windows with an Aluminum Frame and either a Non-Clad Wood Sash or an Aluminum Clad Wood Sash	R-PG50 53 x 35 – Type AP	+50 / -50 psf

### Product Dimensions:

System	Overall Size	Sash Size
1	53" x 35"	53-1/2" x 32-1/2"

**Product Identification (Certification Label on Window):**

System		
1	Certification Agency	WDMA
	Manufacturer's Name or Code Name	Pella
	Product Name	Architect Series Precision Replacement Awning
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08

**Impact Resistance:**

System	Impact Resistant	Requirement
1	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

**Installation:**

System		
1	Type of Installation	Frame
	Wall Framing	Spruce-Pine-Fir Dimension lumber
	Fasteners	Minimum No. 14 x 3-1/4" fillister head screws
	Fastener Location/Spacing	Located in pre-drilled holes along the sill and the head. All pre-drilled holes must be filled.
	Fastener Penetration	Minimum 1-1/2" into the wall framing

**Note:** Keep the manufacturer's installation instructions at the job site during installation. Use corrosion resistant fasteners as specified in the IRC, the IBC, and the Texas Revisions.