

PO Box 149104 | Austin, TX 78714 | 1-800-578-4677 | tdi.texas.gov

# **Product Evaluation**

WIN1581 | 1020

**Engineering Services Program** 

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

**Evaluation ID:** WIN-1581 **Effective Date:** October 1, 2020

**Re-evaluation Date:** October 2024

Product Name: Architect Series Aluminum Clad Wood Vent Awning Windows, Non-Impact

Resistant

Manufacturer: Pella Corporation

102 Main Street Pella, IA 50219 (641) 621-1000

### **General Description:**

System	Description	Label Rating	Design Pressure Rating
1	Pella/Architect Series Clad Wood Vent Awning Windows	CW-PG50 (1346 x 813mm)-AP	+50 / -50 psf
2	Pella/Architect Series Clad Wood Large Vent Awning Windows	LC-PG40 (1524 x 1524mm)-AP	+40 / -40 psf
3	Pella/Architect Series Clad Wood Large Vent Awning Windows	LC-PG30 (1524 x 1854mm)-AP	+30 / -30 psf

#### **Product Dimensions:**

System	Overall Size	Operable Sash Size
1	53" x 32"	51" x 30"
2	59" x 59"	57" x 57"
3	59" x 73"	57" x 71"

## **Product Identification (Certification Label on Window):**

System		
1	Certification Agency	WDMA
	Manufacturer's Name or Code Name	Pella Corporation
	Product Name	Pella/Architect- Awning
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-11
2-3	Certification Agency	WDMA
	Manufacturer's Name or Code Name	Pella Corporation
	Product Name	Pella/Architect-Large Awning
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-11

**Impact Resistance:** 

System	Impact Resistant	Requirement
1-3	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

#### Installation:

System		
	Type of Installation	Install in accordance with Pella Corporation
	Wall Framing	drawing No. 1605T, dated February 5, 2015.
1	Fasteners	Revision A1 dated January 6, 2020. Signed and
	Fastener Location/Spacing	sealed by Warren W. Schaeffer, P.E. on
	Fastener Penetration	July 17, 2020.
	Type of Installation	Install in accordance with Pella Corporation
2-3	Wall Framing	drawing No. 1743T, dated May 11, 2018. Revision
	Fasteners	A1 dated January 6, 2020. Signed and sealed by
	Fastener Location/Spacing	Warren W. Schaeffer, P.E. on
	Fastener Penetration	July 17, 2020.

**Note:** Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.