



Product Evaluation

WIN1652 | 0816

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-1652

Effective Date: August 1, 2016

Re-evaluation Date: August 2020

Product Name: T210 Aluminum Double Hung Windows, Frame Installation, Non-impact Resistant

Manufacturer: NT Windows, Inc.
4949 Rendon Road
Fort Worth, TX 76140
(800) 969-8830

General Description:

System	Description	Label Rating	Design Pressure Rating
1	T210 Aluminum Double Hung Windows; X/X	H-LC40 54 x 77	+40 / -40 psf

Product Dimensions:

System	Overall Size	Exterior Sash Size	Interior Sash Size
1	54" x 77"	50-13/16" x 38"	51-9/16" x 38"

Product Identification (Certification Label on Window):

System		
1	Certification Agency	AAMA
	Manufacturer's Name or Code Name	NT-1
	Product Name	T210 DH
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-05

Impact Resistance:

System	Impact Resistant	Requirement
1	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

Installation:

System		
1	Type of Installation	Frame
	Wall Framing	Spruce-Pine-Fir dimension lumber
	Fasteners	No. 8 x 2" screws
	Fastener Location/Spacing	Along the head and the sill, the fasteners are located approximately 11" from each corner. No fasteners are required along the sill.
	Fastener Penetration	Minimum 1-1/2" into the wall framing.

Note: Keep the manufacturer's installation instructions at the job site during installation. Use corrosion resistant fasteners as specified in the IRC, the IBC, and the Texas Revisions.