

PO Box 149104 | Austin, TX 78714 | 1-800-578-4677 | tdi.texas.gov

Product Evaluation

WIN1767 | 1122

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-1767 **Effective Date:** November 1, 2022

Re-evaluation Date: October 2026

Product Name: Ply Gem 1500 Vinyl Horizontal Sliding Windows, Fin Installation, Non-Impact

Resistant

Manufacturer: Ply Gem Windows

433 North Main St. Rocky Mount, VA 24151 (800) 542-9118 ext. 413596

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Ply Gem 1500 Vinyl Horizontal Sliding Windows; OX	HS-LC50 (63 x 48)	+50 / -50 psf
2	Ply Gem 1500 Vinyl Horizontal Sliding Windows; XOX	HS-LC45 (63 x 44)	+45 / -45 psf
3	Ply Gem 1500 Vinyl Horizontal Sliding Windows; XOX	HS-LC50 (63 x 44)	+50 / -50 psf
4	Ply Gem 1500 Vinyl Horizontal Sliding Windows; OX	HS-LC30 (72 x 56)	+30 / -30 psf
5	Ply Gem 1500 Vinyl Horizontal Sliding Windows; XOX	HS-LC40 (72 x 56)	+40 / -40 psf

General Description:

System	Description	Label Rating	Design Pressure Rating
6	Ply Gem 1500 Vinyl Horizontal Sliding Windows; XOX	HS-LC45 (72 x 56)	+45 / -45 psf
7	Ply Gem 1500 Vinyl Horizontal Sliding Windows; OX	HS-LC25 (72 x 72)	+25 / -25 psf
8	Ply Gem 1500 Vinyl Horizontal Sliding Windows; XOX	HS-LC30 (84 x 63)	+30 / -30 psf
9	Ply Gem 1500 Vinyl Horizontal Sliding Windows; XOX	HS-LC30 (84 x 63)	+30 / -30 psf
10	Ply Gem 1500 Vinyl Horizontal Sliding Windows; XOX	HS-LC25 (96 x 72)	+25 / -25 psf

Product Dimensions:

System	Overall Size	Operable Sash Size	Fixed Sash Daylight Opening Size
1	62-15/16" x 48-1/16"	30-1/16" x 45-1/8"	27-7/8" x 43"
2	63-1/16" x 44"	19-9/16" x 41-1/16" (2)	19" x 39"
3	62-15/16" x 44-1/16"	14-1/4" x 41-1/16" (2)	29-9/16" x 39"
4	72" x 56-1/16"	34-5/8" x 53-5/8"	32-3/8" x 51"
5	72-1/16" x 55-15/16"	Left: 22-9/16" x 53-1/16" Right: 22-1/2" x 53-1/16"	21-15/16" x 51"
6	72-1/16" x 56"	Left: 16-9/16" x 49-5/8" Right: 16-9/16" x 49-9/16"	34" x 51"
7	71-15/16" x 72"	34-5/8" x 69-1/4"	32-3/8" x 67-1/16"
8	84-1/16" x 63"	Left: 26-9/16" x 60-1/8" Right: 26-9/16" x 60-1/4"	25-3/4" x 54"
9	84-1/16" x 62-15/16"	Left: 19-9/16" x 60-1/8" Right: 19-9/16" x 60-3/16"	39-3/4" x 58"
10	96" x 71-15/16"	Left: 22-9/16" x 69-1/8" Right: 22-1/2" x 69-1/8"	45-15/16" x 66-15/16"

Product Identification (Certification Label on Window):

System		
	Certification Agency	NAMI
	Code Name	PWG-M-169-04618-00001 (Systems 1, 3-4, 6-9)
1 10		PWG-M-169-14617-00001 (Systems 2, 5)
1-10		PWG-M-169-04623-0001 (System 10)
	Product Name	Ply Gem 1500 Horizontal Slider
	Test Standards	AAMA/WDMA/CSA 101/ I.S.2/A440-05,08,11

Compliance: The products comply with AAMA/WDMA/CSA 101/I.S.2/A440-17 as referenced in the 2018 IRC and 2018 IBC.

Impact Resistance:

Syste	em	Impact Resistant	Requirement
1-1	10	No	These products have not been tested for windborne debris resistance. An impact protection system is required when installing this product in areas where windborne debris protection is required.

Installation:

System			
	Type of Installation Nail Fin Installation		
	Wall Framing	Southern Yellow Pine dimension lumber	
1-10	Fasteners	No. 8 modified truss head screws	
1-10	Fastener Location/Spacing	4" from each corner and 7.5"-8.5" on center along	
		the perimeter	
	Fastener Penetration	Minimum of 1-1/2" into the wall framing	

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.