



Product Evaluation

WIN1929 | 0914

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-1929 **Effective Date:** September 1, 2014
Re-evaluation Date: March 2017

Product Name: Model 8001 Vinyl Double Hung Window,
Non-Impact Resistant, Replacement Construction

Manufacturer: Alside Window Company/Division of AMI
3773 State Road
Cuyahoga Falls, OH 44223
(330) 922-5350

Distributed Under: Alside
Associated Materials, Inc.
Gentek Building Products
Revere Building Products

General Description:

System	Description	Label Rating	Design Pressure Rating
1	8001 Series Vinyl Double Hung Window; (X/X)	R-PG30 44 x 77	±30 psf
2	8001 Series Vinyl Double Hung Window; (X/X)	R-PG35 44 x 60	±35 psf
3	8001 Series Vinyl Double Hung Window; (X/X)	R-PG35 36 x 72	±35 psf

Product Dimensions:

System	Overall Window Size	Top & Bottom Sash - Max. Daylight Opening Size
1	44" x 77"	36-1/4" x 34"
2	44" x 60"	36-1/4" x 25-1/2"
3	36" x 72"	28-1/4" x 31-1/2"

Product Identification (Certification Agency Label on Window):

System		
1-3	Certification Agency	AAMA
	Manufacturer's Name or Code Name	UL
	Product Name	Model 8001 Vinyl Double Hung Window
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08

Impact Resistance:

System	Impact Resistant	Requirement
1-3	No	Impact protective system required when product is installed in areas where windborne debris protection is required.

Installation:

System		
1-3	Type of Installation	Through Jamb
	Wall Framing	Spruce-Pine-Fir
	Fasteners	No. 10 Wood Screws
	Fastener Location/Spacing	Install windows in accordance with Drawing No. TX-4363, title "Model 8001 Vinyl Double Hung Window 'Non-Impact'," sheets 1 through 4 of 4, dated November 5, 2013. Drawings are signed, sealed and dated August 13, 2014 by Lyndon F. Schmidt, P.E.
	Fastener Penetration	Minimum of 1-1/4" into the wall framing members.

Note: The manufacturer's installation instructions shall be available on the job site during installation. All fasteners shall be corrosion resistant as specified in the International Residential Code (IRC), the International Building Code (IBC), and the Texas Revisions.