



# Product Evaluation

WIN1972 | 0315

Engineering Services Program

*The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).*

*This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.*

*This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.*

*For more information, contact TDI Engineering Services Program at (800) 248-6032.*

**Evaluation ID:** WIN-1972 **Effective Date:** March 1, 2015  
**Re-evaluation Date:** November 2017

**Product Name:** Series 03A2 ST Vinyl Horizontal Slider Windows, Replacement Construction, Non-Impact Resistant

**Manufacturer:** Alside Window Company/Division of AMI  
3773 State Road  
Cuyahoga Falls, OH 44223  
(330) 922-5350

**Distributed Under:** Alside  
Associated Materials, Inc.  
Gentek Building Products  
Revere Building Products

### General Description:

System	Description	Label Ratings	Design Pressure
1	Series 03A2 ST Vinyl Horizontal Slider Window; (OX)	LC-PG25 96x60-HS	±25 psf
2	Series 03A2 ST Vinyl Horizontal Slider Window; (OX)	LC-PG35 72x56-HS	±35 psf

### Product Dimensions:

System	Overall Window Size	Operable Sash Size	Fixed Glass Daylight Opening Size
1	96" x 60"	47-1/8" x 56-7/8"	44-3/8" x 54-1/4"
2	72" x 56"	35-1/8" x 52-7/8"	32-3/8" x 50-1/4"

**Product Identification (Certification Label on Window):**

System		
1, 2	Certification Agency	AAMA
	Manufacturer's Name or Code Name	UL-5
	Product Name	Series 03A2 ST / 03S2 ST Horizontal Slider
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08

**Impact Resistance:**

System	Impact Resistance	Description
1, 2	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

**Installation:**

System		
1, 2	Type of Installation	Install the windows in accordance with Drawing No. TX-4447, titled "Model 03A2 ST Horizontal Slider 'Non-Impact'," sheets 1 through 3 of 3, dated March 27, 2014. Drawing is signed, sealed, and dated April 15, 2014, by Lyndon F. Schmidt, P.E.
	Wall Framing	
	Fasteners	
	Fastener Location/Spacing	
	Fastener Penetration	Minimum 1-1/2" into the Wall Framing

**Note:** Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC, the IBC, and the Texas Revisions.