



Product Evaluation

WIN2049 | 1215

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-2049

Effective Date: December 1, 2015

Re-evaluation Date: October 2018

Product Name: SH-5500 Vinyl Single-Hung Windows, Fin-Mounted and Replacement, Individual, Impact Resistant

Manufacturer: PGT Industries
1070 Technology Drive
North Venice, FL 34275
(941) 486-0100 (Ext. 21142)

General Description:

System	Description	Label Rating	Design Pressure Rating
1	HR-5500 Vinyl Single-Hung Windows, fin-mounted, with a 3/4" nominal insulated glass lite composed of a 1/8" annealed or tempered glass section on the exterior and a 5/16" laminated glass section on the interior; and R2 aluminum reinforcement (O/X)	LC-PG65 52 X 92-H Missile Level D	+65 / -70 psf
2	HR-5500 Vinyl Single-Hung Windows, replacement, with a 3/4" nominal insulated glass lite composed of a 1/8" annealed or tempered glass section on the exterior and a 5/16" laminated glass section on the interior; and R2 aluminum reinforcement (O/X)	LC-PG65 52 X 92-H Missile Level D	+65 / -70 psf

General Description (continued):

System	Description	Label Rating	Design Pressure Rating
3	HR-5500 Vinyl Single-Hung Windows, replacement, with a 3/4" nominal insulated glass lite composed of a 1/8" annealed or tempered glass section on the exterior and a 5/16" laminated glass section on the interior; and R1 aluminum reinforcement (O/X)	LC-PG50 52 X 92-H Missile Level D	+50 / -50 psf
4	HR-5500 Vinyl Single-Hung Windows, replacement, with a 3/4" nominal insulated glass lite composed of a 1/8" annealed or tempered glass section on the exterior and a 5/16" laminated glass section on the interior; and R1 aluminum reinforcement (O/X)	LC-PG50 52 X 92-H Missile Level D	+50 / -50 psf

Product Dimensions:

System	Overall Size	Operable Daylight Opening Size	Fixed Daylight Opening Size
1	54-7/8" x 94-1/2"	45-3/4" x 38-1/16"	47-7/8" x 45-1/8"
2	52-1/8" x 91-3/4"	45-1/2" x 37-3/4"	47-3/4" x 45-5/8"
3	54-7/8" x 94-1/2"	45-3/4" x 38-1/16"	47-7/8" x 45-1/8"
4	52-1/8" x 91-3/4"	45-1/2" x 38"	47-3/4" x 45-5/8"

Note: Refer to the drawings referenced in the Supplemental Installation Instructions for information concerning the configuration of Standard Proview and Custom Sash/Oriel configurations.

Product Identification (Certification Label on Window):

System		
1 - 4	Certification Agency	Keystone Certifications, Inc.
	Manufacturer's Name or Code Name	System 1, 2: CAR # 190-286, 190-1029 System 3, 4: CAR # 190-285, 190-1028
	Product Name	Model SH5500 PVC Imp Single Hung or Model SH5500 View PVC Imp Single Hung
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-11 ASTM E 1886-05/ASTM E 1996-12 Missile Level D

Impact Resistance:

System	Impact Resistant	Requirement
1 - 4	Yes	These products satisfy TDI's criteria for protection from windborne debris in the Inland I and Seaward zone. Install the assemblies at a height on the structure that does not exceed the assemblies' design pressure rating.

Installation:

System		
1, 3 (FIN)	Type of Installation	Wood Frame
	Wall Framing	Southern Pine (SPG \geq 0.55) Dimension lumber
	Fasteners	Minimum 8d Common Ring-Shank Nails (2-1/2" long, 0.131" diameter)
	Fastener Penetration	Minimum 1-7/16" into the wall framing
2, 4 (FINLESS)	Type of Installation	Wood Frame
	Wall Framing	Southern Pine (SPG \geq 0.55) Dimension lumber
	Fasteners	Minimum No. 10 x 1-3/4" Phillips Head, 18-8 or 410 Stainless Steel Sheet Metal Screws or Minimum No. 12 x 1-3/4" Phillips Head, 18-8 or 410 Stainless Steel Sheet Metal Screws
	Fastener Penetration	Minimum 1-1/2" into the wall framing

Supplemental Installation Instructions:

- **Design Drawing:** Install the windows in accordance with Drawing No. TDI-SH5500.1, titled "Vinyl SH Window TDI (Imp.-Resist)," sheets 1 through 4 of 4, dated March 16, 2015, signed and sealed by A. Lynn Miller, P.E., on March 17, 2015. This evaluation report refers to the stated drawings as the approved drawings.

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC, the IBC, and the Texas Revisions.