

PO Box 149104 | Austin, TX 78714 | 1-800-578-4677 | tdi.texas.gov

# **Product Evaluation**

#### WIN2371 | 0519

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at 1-800-248-6032.

**Evaluation ID:** WIN-2371

Effective Date:May 1, 2019Re-evaluation Date:October 2022

Product Name: Series 8313 Vinyl Tilt Double Hung Windows, Frame Installation, Non-Impact Resistant

Manufacturer: Regency Plus, Inc. 2000 Locust Gap Highway Mount Carmel, PA 17851 (570) 339-3374

#### **General Description:**

System	Description	Label Rating	Design Pressure Rating
1	Series 8313 Vinyl Tilt Double Hung Windows (X/X)	LC-PG50 53 x 77-H	+50 / -50 psf

#### **Product Dimensions:**

System	Overall Size	Top Sash Size	Bottom Sash Size
1	53" x 77"	49.063" x 37.188"	50" x 37"

### **Product Identification (Certification Label on Window):**

System		
1	Certification agency	NAMI
	Manufacturer's name or code name	Regency Plus, Inc
	Product name	8313 Vinyl Tilt Double Hung Window
	Test standards	AAMA/WDMA/CSA 101/I.S.2/A440-11

## Impact Resistance:

System	Impact resistant	Requirement
1	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

## Installation:

System		
1	Type of Installation	
	Wall Framing	Install in accordance with Regency Plus, Inc.
	Fasteners	drawing No. RPLS1076 dated November 4, 2018.
	Fastener Location/Spacing	Signed and sealed by Robert James Amoruso, P.E. on November 21, 2018.
	Fastener Penetration	on November 21, 2018.

**Note:** Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC, the IBC, and the Texas Revisions.