# **TDI** Texas Department of Insurance

PO Box 12030 | Austin, TX 78711 | 800-578-4677 | tdi.texas.gov

# **Product Evaluation**

#### WIN2403 | 0222

#### Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-2403

Effective Date:February 1, 2022Re-evaluation Date:July 2024

**Product Name:** Barcelona Model DSL30 Twin and TSL30 Triple Vinyl Horizontal Sliding Windows, Frame Installation, Non-Impact Resistant

Manufacturer: Soft-Lite Windows 10250 Philipp Parkway Streetsboro, OH 44241 (330) 528-3400

#### **General Description:**

System	Description	Label Rating	Design Pressure Rating
1	Series DSL30 Vinyl Twin Horizontal Sliding Windows; XX	LC-PG25 (73 x 63)-HS	+25 / -25 psf
2	Series DSL30 Vinyl Twin Horizontal Sliding Windows; XX	LC-PG40 (73 x 63)-HS	+40 / -40 psf
3	Series DSL30 Vinyl Twin Horizontal Sliding Windows; XX	LC-PG55 (63 x 44)-HS	+55 / -55 psf
4	Series TSL30 Vinyl Triple Horizontal Sliding Window; XOX 1/3-1/3-1/3	LC-PG40 (111 x 63)-HS	+40 / -40 psf

System	Description	Label Rating	Design Pressure Rating
5	Series TSL30 Vinyl Triple Horizontal Sliding Window; XOX LC-PG25 (111 x 63)-H 1/3-1/3-1/3		+25 / -25 psf
6	Series TSL30 Vinyl Triple Horizontal Sliding Window; XOX LC-PG40 (111 x 63)-HS 1/4-1/2-1/4		+40 / -40 psf
7	Series TSL30 Vinyl Triple Horizontal Sliding Window; XOX 1/4-1/2-1/4		+25 / -25 psf
8	Series TSL30 Vinyl Triple Horizontal Sliding Window; XOX 1/3-1/3-1/3	LC-PG50 (96 x 44)-HS	+50 / -50 psf
9	Series TSL30 Vinyl Triple Horizontal Sliding Window; XOX 1/3-1/3-1/3	LC-PG35 (96 x 44)-HS	+35 / -35 psf
10	Series TSL30 Vinyl Triple Horizontal Sliding Window; XOX 1/4-1/2-1/4	LC-PG45 (96 x 44)-HS	+45 / -45 psf
11	Series TSL30 Vinyl Triple Horizontal Sliding Window; XOX 1/4-1/2-1/4	LC-PG30 (96 x 44)-HS	+30 / -30 psf

## **General Description:**

## **Product Dimensions:**

System	Overall Size	Operable Sash Size	Fixed Sash Daylight Opening Size
1-2	73" x 63"	35-7/16" x 58-1/4"	N/A
3	63" x 44"	30-7/16" x 39-1/4"	N/A
4-5	111" x 63"	36-11/16" x 58-1/4"	32-3/4" x 54-1/4"
6-7	111" x 63"	28-1/4" x 58-1/4"	49-3/4" x 54-1/4"
8-9	96" x 44"	31-3/4" x 39-1/4"	27-3/4" x 35-1/4"
10-11	96" x 44"	24-1/2" x 39-1/4"	42-1/4" x 35-1/4"

# Product Identification (Certification Label on Window):

System		
1-3	Certification Agency	NAMI
	Manufacturer's Name or Code Name	Soft-Lite Windows
	Product Name	DSL30 Vinyl Horizontal Sliding Window
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-11

### Product Identification (Certification Label on Window):

System		
4-11	Certification Agency	NAMI
	Manufacturer's Name or Code Name	Soft-Lite Windows
	Product Name	TSL30 Vinyl Horizontal Sliding Window
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-11

#### **Impact Resistance:**

System	Impact Resistant	Requirement
1-11	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

# Installation:

System			
1-3	Type of Installation	Install in accordance with drawing No. TX-4856, dated June 26, 2018. Revision 1 dated May 11, 2021. Signed and sealed by Lyndon F. Schmidt, P.E. on December 15, 2021.	
	Wall Framing		
	Fasteners		
	Fastener Location/Spacing		
	Fastener Penetration		
4-11	Type of Installation	Install in accordance with drawing No. TX-4857 dated June 26, 2018. Revision 1 dated May 11, 2021. Signed and sealed by Lyndon F. Schmidt,	
	Wall Framing		
	Fasteners		
	Fastener Location/Spacing	P.E. on December 15, 2021.	
	Fastener Penetration	1.E. ON December 15, 2021.	

**Note:** Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.