

PO Box 149104 | Austin, TX 78714 | 1-800-578-4677 | tdi.texas.gov

Product Evaluation

WIN740 | 1121

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-740 **Effective Date:** November 1, 2021

Re-evaluation Date: October 2025

Product Name: Series 150/151/160/161 Vinyl Horizontal Sliding Window, Fin Installation, Non-

Impact Resistant

Manufacturer: Atrium Windows and Doors

300 Welcome Center Blvd.

Welcome, NC 27374

(800) 542-9118 ext. 413596

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Series 150/151/160/161 Vinyl Horizontal Sliding Window; XO	R-PG30 (72 x 48)-HS HS-R30 (72 x 48)	+30 / -30 psf
2	Series 150/151/160/161 Vinyl Horizontal Sliding Window; XOX	R-PG25 (108 x 60)-HS HS-R25 (108 x 60)	+25 / -25 psf

Product Dimensions:

System	Overall Size	Operable Sash Size	Fixed Sash Daylight Opening Size
1	72" x 48"	35-1/4" x 45-1/2"	32-5/8" x 43-1/8"
2	108" x 60"	36-1/4" x 57-5/8" (2)	32" x 55" (1)

Product Identification (Certification Label on Window):

System		
	Certification Agency	NAMI
	Manufacturer's Name or Code Name	Atrium Companies
1-2		(Dallas, TX or Welcome, NC)
1-2	Product Name	150/151/160/161 Vinyl Horizontal Sliding
		Window w/ Fin Installation
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-11,08,05

Impact Resistance:

System	Impact Resistant	Requirement
1-2	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

Installation:

The wood wall framing members must be minimum Spruce-Pine-Fir dimension lumber. The window assembly is secured to the wall framing using a nailing fin. The nailing fin is secured to the wall framing using minimum No. 8 wood screws spaced approximately 3" from each corner and 9" on center thereafter along the perimeter. Fasteners must be long enough to penetrate a minimum of 1-1/2" into the wall framing members.

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.