

Product Evaluation

WIN761 | 0922

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-761**Effective Date:** September 1, 2022**Re-evaluation Date:** August 2026

Product Name: Premium Atlantic Vinyl Series 8100 Single Hung Windows, Fin and Frame Installation, Impact Resistant

Manufacturer: JELD-WEN Windows and Doors
3737 Lakeport Boulevard
Klamath Falls, Oregon 97601
(541) 882-3451

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Premium Atlantic Vinyl Series 8100 Single Hung Windows	LC-PG65 36 x 72-H Missile Level D	+65 / -70 psf
2	Premium Atlantic Vinyl Series 8100 Single Hung Windows; Fin Installed	LC-PG50 52 x 75-H Missile Level D	+50 / -60 psf
3	Premium Atlantic Vinyl Series 8100 Single Hung Windows; Fin Installed	LC-PG65 52 x 75-H Missile Level D	+65 / -75 psf

Product Dimensions:

System	Overall Size	Operable Sash Size	Fixed Sash Daylight Opening Size
1	36" x 72"	33.25" x 34.75"	29.875" x 32.5"
2, 3	52.125" x 75"	49.375" x 37.25"	48.625" x 34"

Product Identification (Certification Label on Window):

System		
1, 2, 3	Certification Agency	AAMA
	Manufacturer's Name or Code Name	JW-19
	Product Name	PAV SH (Fin & Flange)
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA 506; ASTM E1886/E1996 Missile Level D

Impact Resistance:

System	Impact Resistant	Requirement
1, 2, 3	Yes	These products have been tested for windborne debris resistance. Install the assemblies at a height on the structure that does not exceed the design pressure rating for the assemblies.

Installation:

System		
1	Type of Installation	Install the windows in accordance with drawing No. NCTL-210-3875-1A; titled "Premium Atlantic Vinyl Single Hung Window;" Sheets 1 thru 10; dated September 02, 2021; signed sealed, and dated November 12, 2021, by Joseph A. Reed, P.E.
	Wall Framing	
	Fasteners	
	Fastener Location/Spacing	
	Fastener Penetration	
2	Type of Installation	Install the windows in accordance with drawing No. NCTL-210-3874-1A; titled "Premium Atlantic Vinyl Single Hung Window;" Sheets 1 thru 10; dated September 2, 2021; signed sealed, and dated November 12, 2021, by Joseph A. Reed, P.E.
	Wall Framing	
	Fasteners	
	Fastener Location/Spacing	
	Fastener Penetration	
3	Type of Installation	Install the windows in accordance with drawing No. NCTL-210-3873-1A; titled "Premium Atlantic Vinyl Single Hung Window;" Sheets 1 thru 10; dated September 2, 2021; signed sealed, and dated November 12, 2021, by Joseph A. Reed, P.E.
	Wall Framing	
	Fasteners	
	Fastener Location/Spacing	
	Fastener Penetration	

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.