

## Product Evaluation

DR1075 | 0322

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at 800-248-6032.

**Evaluation ID:** DR-1075

**Effective Date:** March 1, 2022

**Re-evaluation Date:** March 2026

**Product Name:** Series "Bator Hurricane Four Fold Door" Steel Bi-Folding Door, Impact Resistant

**Manufacturer:** Bator North America, LLC  
1451 South Elm-Eugene St., Ste. 2211  
Greensboro, NC 27406  
(336) 209-9485

### General Description:

System	Description	Label Rating	Design Pressure Rating
1	Series "Bator Hurricane Four Fold Door" Steel Bi-Folding Door; XXXX	189.25 x 192 Large Missile Impact Rated	+120 / -120 psf

### Product Dimensions:

System	Overall Size	Operable Panel Size	Panel Daylight Opening Size
1	189-1/4" x 192"	41-1/8" x 190-1/4" (4)	33" x 58"

**Components and Hardware:**

System	Component	Quantity	Attachment Method
1	Brugger Mechanik AG Hinges	3	Install hardware in accordance with drawing No. BNA002, dated November 14, 2018. Revision A dated January 2022. Signed and sealed by Hermes F. Norero, P.E. on February 7, 2022.
	Bator Multi-point Lock	2	

**Product Identification (Certification Label on Door):**

System		
1	Certification agency	NAMI
	Manufacturer's name or code name	Bator North America LLC
	Product name	Bator Hurricane Four Fold Steel Bi-Folding Door (XXXX)
	Test standards	TAS 201/202/230-94 Large Missile Impact Rated

**Impact Resistance:**

System	Impact Resistant	Requirement
1	Yes	These products satisfy TDI's criteria for protection from windborne debris. Install the assemblies at a height on the structure that does not exceed the design pressure rating for the assemblies.

**Installation:**

System		
1	Type of installation	Install in accordance with drawing No. BNA002, dated November 14, 2018. Revision A dated January 2022. Signed and sealed by Hermes F. Norero, P.E. on February 7, 2022.
	Wall framing	
	Fasteners	
	Fastener location/spacing	
	Fastener penetration	

**Note:** Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.