

## Product Evaluation

DR1095 | 0720

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at 800-248-6032.

**Evaluation ID:** DR-1095

**Effective Date:** July 1, 2020

**Re-evaluation Date:** April 2024

**Product Name:** Series 8900 Vinyl Sliding Glass Doors, Non-Impact Resistant

**Manufacturer:** Custom Window Systems  
1900 SW 44<sup>th</sup> Avenue  
Ocala, FL 34474  
(352) 368-6922

### General Description:

System	Description	Label Rating	Design Pressure Rating
1	Series 8900 Vinyl Sliding Glass Doors (OXXO)	LC-PG60 (190 x 96)	+60 / -60 psf

### Product Dimensions:

System	Overall Size	Operable Panel Size	Fixed Panel Daylight Opening Size
1	190.125" x 95.50"	48.625" x 93"	41.50" x 85.875"

**Product Identification (Certification Label on Door):**

System		
1	Certification agency	Keystone
	Manufacturer's name or code name	CAR# 138-1619
	Product name	8900 PVC Sliding Glass Door
	Test standards	AAMA/WDMA/CSA 101/I.S.2/A440-11,17

**Impact Resistance:**

System	Impact Resistant	Requirement
1	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

**Acceptance of Smaller Assemblies:** Door assemblies with dimensions equal to or smaller than those specified are acceptable within the limitations of this report.

**Installation:**

System		
1	Type of installation	Install in accordance with Custom Window Systems drawing No. TDI-496, dated October 30, 2009. Signed and sealed by Lucas A. Turner, P.E. on March 16, 2020.
	Wall framing	
	Fasteners	
	Fastener location/spacing	
	Fastener penetration	

**Note:** Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.