

## Product Evaluation

DR191 | 0320

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at 800-248-6032.

**Evaluation ID:** DR-191

**Effective Date:** March 1, 2020

**Re-evaluation Date:** October 2023

**Product Name:** 400 Series Frenchwood Gliding Patio Doors, Model FWG160611SAAS, Non-Impact Resistant

**Manufacturer:** Andersen Corporation  
100 4<sup>th</sup> Avenue North  
Bayport, MN 55003  
(651) 264-5308

### General Description:

System	Description	Label Rating	Design Pressure Rating
1	400 Series Frenchwood Gliding Patio Doors; 4-Panel	LC-PG25 (189 x 82.4)	+25 / -25 psf

### Product Dimensions:

System	Overall Size	Operable Panel Size	Fixed Panel Daylight Opening Size
1	189" x 82-3/8"	48" x 79-1/16"	39-1/8" x 66"

**Product Identification (Certification Label on Door):**

System		
1	Certification agency	WDMA
	Manufacturer's name or code name	Andersen Corporation
	Product name	400 Series Frenchwood Gliding Patio Door
	Test standards	AAMA/WDMA/CSA 101/I.S.2/A440-08, 11

**Impact Resistance:**

System	Impact Resistant	Requirement
1	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

**Installation:**

The wood wall framing members must be minimum Spruce-Pine-Fir dimension lumber. The door assembly is secured to the wall framing using minimum No. 10 x 3" screws along the head and side jambs. Along the side jambs, locate the screws approximately 10" from each corner and at the mid-span. Along the head, locate the screws approximately 8" from each corner and 21" on center. Fasteners must be long enough to penetrate a minimum of 1-1/2" into the wall framing members.

**Note:** Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.