

## Product Evaluation

DR432 | 1123

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at 800-248-6032.

**Evaluation ID:** DR-432

**Effective Date:** November 1, 2023

**Re-evaluation Date:** November 2027

**Product Name:** 6'-8" Opaque Steel Side Hinged Doors, Outswing, Singles and Doubles, Impact Resistant

**Manufacturer:** Steves and Sons  
203 Humble Avenue  
San Antonio, TX 78225  
(210) 924-0470

### General Description:

System	Description	Label Rating	Drawing Number
1	3'-0" x 6'-8" Single Door	+50 / -50 psf Missile Level D	TX-4083
2	6'-0" x 6'-8" Double Door	+50 / -50 psf Missile Level D	TX-4083

### Product Dimensions:

System	Overall Size	Operable Panel Size	Fixed Panel Daylight Opening Size
1	37.50" x 81.25"	35.75" x 79.50"	N/A
2	74" x 81.25"	35.75" x 79.50"	N/A

**Components and Hardware:**

System	Component	Quantity	Attachment Method
1-2	Hinges	3	Install in accordance with Steves & Sons drawing No. TX-4083, dated May 17, 2010. Revision 3 dated July 17, 2023. Signed and sealed by Lyndon F. Schmidt, P.E. on July 17, 2023
	Lock: Kwikset Signature Series Deadbolt: Kwikset Signature Series (980) OR Lock: Schlage F51 Deadbolt: Schlage B60N	1 each	
	Latch & Deadbolt strike plate	1 each	

**Product Identification (Manufacturer Label on Door):**

System		
1-2	Certification agency	Self-labeled
	Manufacturer's name or code name	Steves & Sons
	Product name	Opaque Steel Side Hinged Doors, Outswing, Impact Resistant Door Panels, Singles & Doubles
	Test standards	ASTM E330-14/E1886-13a/E1996-14a Missile Level D

**Impact Resistance:**

System	Impact Resistant	Requirement
1-2	Yes	These products satisfy TDI's criteria for protection from windborne debris. Install the assemblies at a height on the structure that does not exceed the design pressure rating for the assemblies.

**Installation:**

System		
1-2	Type of installation	Install in accordance to Steves & Sons drawing No. TX-4083, dated May 17, 2010. Revision 3 dated July 17, 2023. Signed and sealed by Lyndon F. Schmidt, P.E. on July 17, 2023
	Wall framing	
	Fasteners	
	Fastener location/spacing	
	Fastener penetration	

**Note:** Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.