

Product Evaluation

WIN1127 | 1020

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-1127

Effective Date: October 1, 2020

Re-evaluation Date: October 2024

Product Name: Ultimate Aluminum Clad Wood Casement Picture Windows, Frame Installation, Non-Impact Resistant

Manufacturer: Marvin
Hwy 11 West
Warroad, MN 56763
(800) 346-5044

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Ultimate Clad Wood Casement Picture Windows	CW-PG50 (64 x 104)	+50 / -50 psf
2	Ultimate Clad Wood Casement Picture Windows	CW-PG50 (72 x 71.12)	+50 / -50 psf
3	Ultimate Clad Wood Casement Picture Windows	CW-PG50 (88 x 96.12)	+50 / -50 psf
4	Ultimate Clad Wood Casement Picture Windows	CW-PG40 (80 x 120)	+40 / -40 psf
5	Ultimate Clad Wood Casement Picture Windows	CW-PG50 (60 x 99)	+50 / -50 psf

Product Dimensions:

System	Overall Size	Fixed Sash Daylight Opening Size
1	64" x 104"	58-1/4" x 98-3/16"
2	72" x 71-1/8"	66-1/4" x 65-3/8"
3	88" x 96-1/8"	82-1/4" x 90-3/8"
4	80" x 120"	74-1/4" x 114-1/4"
5	60" x 99"	54-3/16" x 93-1/4"

Product Identification (Certification Label on Window):

System		
1	Certification Agency	WDMA
	Manufacturer's Name or Code Name	Marvin
	Product Name	UL CSMNT NFP, UL CSMNT POP, UL CSMNT P, or UL CSMNT NFPOP
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08,11
2-4	Certification Agency	WDMA
	Manufacturer's Name or Code Name	Marvin
	Product Name	UL CSMNT POP or UL CSMNT P
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-11,17
5	Certification Agency	WDMA
	Manufacturer's Name or Code Name	Marvin
	Product Name	UL CSMNT NFP or UL CSMNT P
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-11,17

Impact Resistance:

System	Impact Resistant	Requirement
1-5	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

Installation:

System		
1-5	Type of Installation	Screw Through Frame
	Wall Framing	Spruce-Pine-Fir
	Fasteners	No. 8 x 3" screws
	Fastener Location/Spacing	4" from each corner and 15" on center along the perimeter
	Fastener Penetration	Minimum of 1-1/2" into the wall framing

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.