



# Product Evaluation

WIN1545 | 0316

Engineering Services Program

*The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).*

*This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.*

*This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.*

*For more information, contact TDI Engineering Services Program at (800) 248-6032.*

**Evaluation ID:** WIN-1545 **Effective Date:** March 1, 2016  
**Re-evaluation Date:** August 2020

**Product Name:** Series GA 508 (6000/6300) HS Aluminum Horizontal Sliding Windows, New Construction, Non-Impact Resistant

**Manufacturer:** MI Windows & Doors, LLC  
1001 W Crosby Rd.  
Carrollton, TX 75006-6901  
(972) 242-5271

### General Description:

System	Description	Label Rating	Design Pressure Rating
1	Series GA 508 (FIN) Aluminum Horizontal Sliding Windows; XOX	LC-PG25 120 x 60-HS	+25 / -25 psf

### Product Dimensions:

System	Overall Size	Fixed Daylight Opening Size	Sash Daylight Opening Size
1	120" x 60"	45-1/8" x 56-3/4"	33-1/8" x 56-5/8"

### Product Identification (Certification Label on Window):

System		
1	Certification Agency	AAMA
	Manufacturer's Name or Code Name	MTL-12
	Product Name	GA 508 (6000/6300) HS
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08

**Impact Resistance:**

System	Impact Resistant	Requirement
1	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

**Installation:**

System		
1 (FIN)	Type of Installation	Mounting Fin
	Wall Framing	Spruce-Pine-Fir dimension lumber
	Fasteners	Minimum 6d (2" long) common wire nails
	Fastener Location/Spacing	Drive fasteners around the entire window perimeter through the nail fin at approximately 6" from each corner and at 19" on center thereafter.
	Fastener Penetration	Minimum 1-1/2" into the wall framing

**Note:** Keep the manufacturer's installation instructions at the job site during installation. Use corrosion resistant fasteners as specified in the IRC, the IBC, and the Texas Revisions.