

Product Evaluation

WIN1856 | 0622

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-1856

Effective Date: June 1, 2022

Re-evaluation Date: January 2026

Product Name: Series 143.000 Wet Glazed Vinyl Picture Windows, Fin and Frame Installation, Non-Impact Resistant

Manufacturer: Showcase Windows and Doors
12613 Citypark Dr. Unit 100
Missouri City, TX 77489
(713) 926-8500

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Series 143.000 Wet Glazed Vinyl Picture Windows; Frame Installation	FW-C80 (64 x 84)	+80 / -80 psf
2	Series 143.000 Wet Glazed Vinyl Picture Window; Frame Installation	FW-C80 (50 x 63)	+80 / -80 psf
3	Series 143.000/145.000 Wet Glazed Vinyl Picture Window; Fin Installation	FW-C80 (60 x 60)	+80 / -80 psf
4	Series 143.000 Wet Glazed Vinyl Picture Window; Fin Installation	FW-R80 (72 x 48)	+80 / -80 psf

General Description:

System	Description	Label Rating	Design Pressure Rating
5	Series 143.000 Wet Glazed Vinyl Picture Window; Fin Installation	FW-C80 (64 x 84)	+80 / -80 psf
6	Series 143.000 Wet Glazed Vinyl Picture Window; Fin Installation	FW-C75 (50 x 63)	+75 / -75 psf

Product Dimensions:

System	Overall Size	Fixed Sash Daylight Opening Size
1, 5	64" x 84"	59" x 70"
2, 6	50" x 63"	45" x 58"
3	60" x 60"	55" x 55"
4	72" x 48"	67" x 43"

Product Identification (Certification Label on Window):

System		
1-2	Certification Agency	Keystone
	Manufacturer's Name or Code Name	CAR# 839-769 (System 1) CAR# 839-771 (System 2)
	Product Name	143.000 Wet Glazed Picture Window
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-05
3-4	Certification Agency	Keystone
	Manufacturer's Name or Code Name	CAR# 839-791 (System 3) CAR# 839-793 (System 4)
	Product Name	143.000/145.000 Wet Glazed Picture Window
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-05
5-6	Certification Agency	Keystone
	Manufacturer's Name or Code Name	CAR# 839-1061 (System 5) CAR# 839-1063 (System 6)
	Product Name	143.000 NC Picture Window
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-05

Impact Resistance:

System	Impact Resistant	Requirement
1-6	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

Installation:

System		
1-2	Type of Installation	Frame Installation
	Wall Framing	Spruce-Pine-Fir dimension lumber
	Fasteners	No. 8 PH screws
	Fastener Location/Spacing	6" from each corner and one at the midspan along the side jambs
	Fastener Penetration	Minimum of 1-1/2" into the wall framing
3-6	Type of Installation	Fin Installation
	Wall Framing	Spruce-Pine-Fir dimension lumber
	Fasteners	No. 8 PH screws
	Fastener Location/Spacing	At each corner and 12" on center along the perimeter
	Fastener Penetration	Minimum of 1-1/2" into the wall framing

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.