

Product Evaluation

WIN1898 | 0124

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-1898

Effective Date: January 1, 2024

Re-evaluation Date: January 2028

Product Name: 400/500 Series Vinyl Double Hung Windows, Fin Installation, Non-Impact Resistant

Manufacturer: Wincore Window Company
250 Staunton Avenue
Parkersburg, WV 26104
(304) 485-7460

General Description:

System	Description	Label Rating	Design Pressure Rating
1	400/500 Series Vinyl Double Hung Window; X/X	R-PG35 44 x 60-H	+35/-35 psf
2	400/500 Series Vinyl Double Hung Window; X/X	R-PG45 32 x 78-H	+45/-45 psf
3	400/500 Series Vinyl Double Hung Window; X/X	R-PG30 40 x 68-H	+30/-30 psf
4	400/500 Series Vinyl Double Hung Window; X/X	R-PG30 52 x 63-H	+30/-30 psf
5	400/500 Series Vinyl Double Hung Window; X/X	R-PG50 36 x 68-H	+50/-50 psf

General Description (Continued):

System	Description	Label Rating	Design Pressure Rating
6	400/500 Series Vinyl Double Hung Window; X/X	R-PG50 38 x 59-H	+50/-50 psf
7	400/500 Series Vinyl Double Hung Window; X/X	R-PG35 46 x 77-H	+35/-35 psf

Product Dimensions:

System	Overall Size	Maximum Daylight Opening Size
1	44" x 60"	38 1/4" x 26 3/8"
2	32" x 78"	26 1/4" x 35 3/8"
3	40" x 68"	34 1/4" x 30 3/8"
4	52" x 63"	46 1/4" x 27 7/8"
5	36" x 68"	30 1/4" x 30 3/8"
6	38" x 59"	32 1/4" x 25 7/8"
7	46" x 77"	40 1/4" x 34 7/8"

Product Identification (Certification Label on Window):

System		
1-7	Certification Agency	NAMI
	Manufacturer's Name or Code Name	Wincore Window Company, LLC
	Product Name	400 Series Vinyl Double Hung Window OR 500 Series Vinyl Double Hung Window
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-17

Impact Resistance:

System	Impact Resistant	Requirement
1-7	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

Acceptance of Smaller Assemblies: Window assemblies with dimensions equal to or smaller than those specified are acceptable with the limitations specified in this report.

Installation:

System	Impact Resistant	Requirement
1-7	Type of Installation	Install the window in accordance with Drawing No. TX-4344, titled: Series 400 Vinyl Double Hung Window "Non-Impact", Sheets 1 through 3 of 3, dated 8/14/13, Revision 2, dated 1/20/20 or drawing TX-4345, titled: Series 500 Vinyl Double Hung Window "Non-Impact", Sheets 1 through 3 of 3, dated 8/14/13, Revision 2, dated 1/20/20. Drawings signed, sealed, and dated 2-18-20 by Lyndon F. Schmidt, P.E.
	Wall Framing	
	Fasteners	
	Fastener Location/Spacing	
	Fastener Penetration	

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.