

Product Evaluation

WIN2219 | 1120

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-2219

Effective Date: November 1, 2020

Re-evaluation Date: September 2023

Product Name: 8200 Series Vinyl Horizontal Slider Windows, Fin and Frame Installation, Impact Resistant

Manufacturer: Custom Window Systems, Inc.
1900 SW 44th Avenue
Ocala, FL 34474
(352) 368-6922

General Description:

System	Description	Label Rating	Design Pressure Rating
1	8200 Series Vinyl Horizontal Slider Windows; OX	LC-PG50 (74 x 63)-HS Missile Level D	+50 / -50 psf
2	8200 Series Vinyl Horizontal Slider Windows; OX	LC-PG60 (74 x 63)-HS Missile Level D	+60 / -60 psf
3	8200 Series Vinyl Horizontal Slider Windows; XOX	LC-PG60 (111 x 63)-HS Missile Level D	+50 / -50 psf
4	8200 Series Vinyl Horizontal Slider Windows; XOX	LC-PG60 (111 x 63)-HS Missile Level D	+60 / -60 psf

Product Dimensions:

System	Overall Size	Operable Sash Size	Fixed Sash Daylight Opening Size
1-2	74" x 63"	36-5/16" x 59-9/16"	33" x 58-13/16"
3-4	111" x 63"	27-15/16" x 59-9/16" (2)	49-15/16" x 58-13/16"

Product Identification (Certification Label on Window):

System		
1-2	Certification Agency	Keystone
	Manufacturer's Name or Code Name	CAR# 138-1086 (Sys. 1); 138-1085 (Sys. 2) (Structural) CAR# 138-524 (Sys. 1); 138-523 (Sys. 2) (Impact)
	Product Name	8200 PVC Fin/Flange Impact Horizontal Slider
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08 ASTM E1886-02,05/E1996-02,09 Missile Level D
3-4	Certification Agency	Keystone
	Manufacturer's Name or Code Name	CAR# 138-1087 (Sys. 3-4) (Structural) CAR# 138-526 (Sys. 3); 138-525 (Sys. 4) (Impact)
	Product Name	8200 PVC Fin/Flg Impact 1/4 - 1/2 - 1/4 XOX Slider
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08 ASTM E1886-02,05/E1996-02,09 Missile Level D

Impact Resistance:

System	Impact Resistant	Requirement
1-4	Yes	These products satisfy TDI's criteria for protection from windborne debris in the Inland I and Seaward zone. Install the assemblies at a height on the structure that does not exceed the design pressure rating for the assemblies.

Installation:

System		
1-3	Type of Installation	Install in accordance with Custom Window Systems drawings No. TDI-867, 871, and TDI-868, dated November 12, 2015. Revision B dated April 29, 2020. Signed and sealed by Lucas A. Turner, P.E. on May 28, 2020.
	Wall Framing	
	Fasteners	
	Fastener Location/Spacing	
	Fastener Penetration	

Installation (continued):

System		
4	Type of Installation	Install in accordance with Custom Window Systems drawings No. TDI-869 dated November 12, 2015. Revision B dated May 8, 2020. Signed and sealed by Lucas A. Turner, P.E. on May 29, 2020.
	Wall Framing	
	Fasteners	
	Fastener Location/Spacing	
	Fastener Penetration	

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.