

Product Evaluation

WIN2260 | 0422

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-2260

Effective Date: April 1, 2022

Re-evaluation Date: April 2023

Product Name: Emerge E300 (340) (E700) Aluminum Two-Lite Fixed Window Muller to Aluminum Louver, Impact Resistant

Manufacturer: Quaker Window Products Co., Inc.
504 Highway 63 South
Freeburg, MO 65035
(800) 347-0438

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Emerge Aluminum Two-Lite Fixed Window Muller to Louver; OO/O	CW-PG50 (72 x 95)-FW Missile Level D	+50 / -50 psf

Product Dimensions:

System	Overall Size	Fixed Sash Daylight Opening Size
1	72" x 94-3/4"	33-3/8" x 68-3/4"

Product Identification (Certification Label on Window):

System		
1	Certification Agency	NAMI
	Manufacturer's Name or Code Name	Quaker Window Products
	Product Name	Emerge E300 (340) (E700) Fixed Window(s) Muller to Aluminum Louver
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08,11 ASTM E1886-02/E1996-02,05 AAMA 450-10 Missile Level D

Impact Resistance:

System	Impact Resistant	Requirement
1	Yes	These products satisfy TDI's criteria for protection from windborne debris. Install the assemblies at a height on the structure that does not exceed the design pressure rating for the assemblies.

Installation:

System		
1	Type of Installation	Install in accordance with drawing No. QWP015, dated February 24, 2017; revised January 2021. Signed and sealed by Hermes F. Norero, P.E. on February 13, 2022.
	Wall Framing	
	Fasteners	
	Fastener Location/Spacing	
	Fastener Penetration	

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.