

## Product Evaluation

WIN2349 | 0721

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at 1-800-248-6032.

**Evaluation ID:** WIN-2349

**Effective Date:** July 1, 2021

**Re-evaluation Date:** March 2024

**Product Name:** Barcelona Model SSL30I & TSL30I Vinyl, Horizontal Sliding Windows, Frame Installation, Impact Resistant

**Manufacturer:** Soft-Lite Windows  
10250 Philipp Parkway  
Streetsboro, OH 44241  
(330) 528-3400

### General Description:

System	Description	Label Rating	Design Pressure Rating
1	Barcelona Model SSL30I Horizontal Sliding Window, Frame Installation (O/X)	R-PG50 (73 x 63)- HS Missile Level C	+50 / -55 psf
2	Barcelona Model SSL30I Horizontal Sliding Window; Frame Installation (O/X)	R-PG55 (73 x 63)- HS Missile Level D	+55 / -60 psf
3	Barcelona Model SSL30I Horizontal Sliding Window; Frame Installation (O/X)	R-PG55 (73 x 56)- HS Missile Level C	+55 / -60 psf

**General Description (Continued):**

System	Description	Label Rating	Design Pressure Rating
4	Barcelona Model SSL30I Horizontal Sliding Window Frame Installation (O/X)	R-PG55 (73 x 56)- HS Missile Level D	+55 / -60 psf
5	Barcelona Model SSL30I Horizontal Sliding Window Frame Installation (O/X)	R-PG60 73 x 48-HS Missile Level C	+60 / -65 psf
6	Barcelona Model SSL30I Horizontal Sliding Window Frame Installation (O/X)	R-PG60 73 x 48-HS Missile Level D	+60 / -65 psf
7	Barcelona Model TSL30I Horizontal Sliding Window Frame Installation (X/O/X)	R-PG50 111 x 63-HS Missile Level C	+50 / -55 psf
8	Barcelona Model TSL30I Horizontal Sliding Window Frame Installation (X/O/X)	R- PG50 111 x 63-HS Missile Level C	+50 / -55 psf
9	Barcelona Model TSL30I Horizontal Sliding Window; Frame Installation (X/O/X)	R-PG55 111x 63-HS Missile Level D	+55 / -60 psf
10	Barcelona Model TSL30I Horizontal Sliding Window; Frame Installation (X/O/X)	R-PG55 111 x 63-HS Missile Level D	+55 / -60 psf

**Product Dimensions:**

System	Overall Size	Operable Sash Size	Fixed Daylight Opening Size
1, 2	73" x 63"	35.312" x 58.312"	31.437" x 54.375"
3, 4	73" x 56"	35.375" x 51.312"	31.437" x 47.375"
5, 6	73" x 48"	35.375" x 43.312"	31.437" x 39.375"
7, 9	111" x 63"	Two: 36.75" x 58.25"	32.75" x 54.25"
8, 10	111" x 63"	Two: 28.187" x 58.25"	49.75" x 54.25"

**Product Identification (Certification Label on Window):**

System		
1, 3, 5	Certification agency	NAMI
	Manufacturer's name or code name	Soft-Lite Windows
	Product name	Barcelona Vinyl Horizontal Sliding Window (SSL30I)
	Test standards	AAMA/WDMA/CSA 101/I.S.2/A440-11, ASTM E 1886-05, E 1996-09 Missile Level C

**Product Identification (Certification Label on Window) - Continued:**

System		
2, 4, 6	Certification agency	NAMI
	Manufacturer's name or code name	Soft-Lite Windows
	Product name	Barcelona Vinyl Horizontal Sliding Window (SSL30I)
	Test standards	AAMA/WDMA/CSA 101/I.S.2/A440-11, ASTM E1886-05/E1996-09; Missile Level D
7, 8	Certification agency	NAMI
	Manufacturer's name or code name	Soft- Lite Windows
	Product name	Barcelona Vinyl Horizontal Sliding Window (TSL30I)
	Test standards	AAMA/WDMA/CSA 101/I.S.2/A440-11, ASTM E1886-05/E1996-09; Missile Level C
9, 10	Certification agency	NAMI
	Manufacturer's name or code name	Soft- Lite Windows
	Product name	Barcelona Vinyl Horizontal Sliding Window (TSL30I)
	Test standards	AAMA/WDMA/CSA 101/I.S.2/A440-11, ASTM E1886-05/E1996-09; Missile Level D

**Impact Resistance:**

System	Impact Resistant	Requirement
1, 3, 5, 7, 8	Yes	These products satisfy TDI's criteria for protection from windborne debris. The products may be used for Basic Protection in areas where the basic ultimate wind speed is less than 150 mph at a distance greater than 1 mile from the coastline. Install the assemblies at a height on the structure that does not exceed the design pressure rating for the assemblies
2, 4, 6, 9, 10	Yes	These products satisfy TDI's criteria for protection from windborne debris. Install the assemblies at a height on the structure that does not exceed the design pressure rating for the assemblies.

**Installation:**

System		
1-6	Type of Installation	Install in accordance with Soft-Lite Windows drawing No. TX-4858, dated June 26, 2018, Revision 1 dated May 11, 2021. Signed and sealed by Lyndon F. Schmidt, P.E. on May 17, 2021.
	Wall Framing	
	Fasteners	
	Fastener Location/Spacing	
	Fastener Penetration	
7-10	Type of Installation	Install in accordance with Soft-Lite Windows drawing No. TX-4859, dated June 26, 2018. Revision 1 dated May 11, 2021. Signed and sealed by Lyndon F. Schmidt, P.E. on May 17, 2021.
	Wall Framing	
	Fasteners	
	Fastener Location/Spacing	
	Fastener Penetration	

**Note:** Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.