

## Product Evaluation

WIN2378 | 0122

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at 1-800-248-6032.

**Evaluation ID:** WIN-2378

**Effective Date:** January 1, 2022

**Re-evaluation Date:** December 2024

**Product Name:** Series 5951 Vinyl Transom Fixed Window, Fin and Frame Installation, Non-Impact Resistant

**Manufacturer:** Window Mart Mfg., LLC  
5760 Albert Pike  
Royal, Arkansas 71968  
(501) 760-4730

### General Description:

| System | Description                             | Label Rating      | Design Pressure Rating |
|--------|---|-------------------|------------------------|
| 1      | Series 5951 Vinyl Fixed Window; Transom | R-PG70 96 x 36-FW | +70 / -70 psf          |

### Product Dimensions:

| System | Overall Size | Operable Sash Size | Maximum Fixed Daylight Opening Size |
|--------|--------------|--------------------|-------------------------------------|
| 1      | 96" x 36"    | N/A                | 91-3/4" x 31-3/4"                   |

**Product Identification (Certification Label on Window):**

| System |                                  |                                 |
|--------|----------------------------------|---------------------------------|
| 1      | Certification agency             | Keystone                        |
|        | Manufacturer's name or code name | CAR# 588-480                    |
|        | Product name                     | 5951 PVC Transom Picture Window |
|        | Test standards                   | AAMA/WDMA/CSA 101/I.S.2/A440-11 |

**Impact Resistance:**

| System | Impact resistant | Requirement  |
|--------|------------------|--|
| 1      | No               | Provide an impact protective system when installing the product in areas that require windborne debris protection. |

**Installation:**

| System |                           |   |
|--------|---------------------------|---|
| 1      | Type of Installation      | Install in accordance with Window Mart drawing No. 08-03271 dated July 3, 2018; revision A dated November 3, 2021. Signed and sealed by Luis R. Lomas, P.E. on November 16, 2021. |
|        | Wall Framing              |   |
|        | Fasteners                 |   |
|        | Fastener Location/Spacing |   |
|        | Fastener Penetration      |   |

**Note:** Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.