

Product Evaluation

WIN2408 | 0919

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-2408

Effective Date: September 1, 2019

Re-evaluation Date: September 2023

Product Name: H3 Aluminum Clad, Vinyl, Wood Main Frame Triple Slider Muller Above H3 2.0 Direct Set Window, Non-Impact Resistant

Manufacturer: Sierra Pacific Windows
575 South Whelen Ave
Medford, WI 54451
(715) 748-2011

General Description:

System	Description	Label Rating	Design Pressure Rating
1	H3 Triple Slider Muller Above H3 2.0 Direct Set Window	LC-PG50 (120 x 96)-HS LC-PG50 Span (120) x TW (48)-MA	+50 / -50 psf

Product Dimensions:

System	Overall Size	Horizontal Slider	Direct Set (Fixed)
1	120" x 95.75"	Overall Size: 120" x 59.50" Operable Sash: 30.44" x 56.63" Fixed DLO: 55.875" x 53.625"	Overall Size: 120" x 36" DLO: 56.813" x 32.313" (Center) DLO: 26.563" x 32.313" (End)

Product Identification (Certification Label on Window):

System		
1	Certification Agency	WDMA
	Manufacturer's Name or Code Name	Sierra Pacific Windows
	Product Name	H3 Triple Slider Un-Equal Lites Mull
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-11

Impact Resistance:

System	Impact Resistant	Requirement
1	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

Installation:

The wood wall framing members must be minimum Spruce-Pine-Fir dimension lumber. The window assembly is secured to the wall framing using an integral aluminum nailing flange at the direct set window and an integral vinyl nailing flange at the triple slider window. The nailing flange is secured to the wall framing using minimum No. 8 PPH screws. Locate the screws approximately 2"-4" from the corners and 4"-7" on center. Secure an installation clip approximately 3" on each side of the mull at each end, at the head of the Triple Slider at the meeting rail locations and at the sill of the Direct Set at the mull post/jamb locations. Clips must be minimum 5" long, 1.5" wide, and made of 20-gauge galvanized steel. Secure the clips to the window frame using three minimum No. 6 PFH screws and the wall framing using minimum No. 8 PPH screws. Fasteners must be long enough to penetrate a minimum of 1-1/2" into the wall framing members.

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC, the IBC, and the Texas Revisions.