

## Product Evaluation

WIN2708 | 0522

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

**Evaluation ID:** WIN-2708

**Effective Date:**

May 1, 2022

**Re-evaluation Date:**

May 2026

**Product Name:** Traco NX-3800 Aluminum Fixed Windows, Non-Impact Resistant

**Manufacturer:** Kawneer Company, Inc.  
Technology Park/ Atlanta  
555 Guthridge Court  
Norcross, GA 30092-3503  
(770) 449-5555

### General Description:

The Traco NX-3800 aluminum fixed windows are used for commercial installation. This evaluation report includes the following assemblies:

- Individual Fixed Window

**Product Identification:** A Kawneer label will be affixed to the window assembly. The label includes the manufacturer's name (Kawneer); the product name (Traco NX-3800 Windows-Fixed); the design pressures (+/- 80 psf); the max. assembly size (60"w x 99"h); the configuration (O); TDI drawing I-NX3800-001; and the test standards (AAMA/WDMA/CSA 101/I.S.2/A440-08).

**Compliance:**

The window assemblies were tested for compliance with AAMA/WDMA/CSA 101/I.S.2/A440-08; however, they are not certified by an inspection agency and do not bear a performance label from an inspection agency. The window bears a label produced by the manufacturer.

The window assemblies passed test criteria equivalent to ASTM E330-14.

**Limitations:**

**Design Drawings:** The window assemblies must comply with and be installed in accordance with the following design drawings:

- Drawing No. I-NX3800-001, titled "NX-3800-Fixed Window, Non-Impact;" Sheets 1 thru 3 of 3; dated May 23, 2012; signed and sealed by Lucas A. Turner, P.E. on March 3, 2022. This evaluation report refers to the stated drawing as the approved drawing.

**Fabrication and Assembly:** Kawneer window systems are fabricated in the factory. The aluminum window system is assembled and glazed at the jobsite. The approved drawings referenced in this evaluation report indicate the options for the glazing construction.

**Design Pressure (DP):** The aluminum window system has a maximum design pressure rating of +80 / -80 psf. Refer to the approved drawing for specific design pressure requirements.

**Impact Resistance:** The window system does not satisfy TDI's criteria for protection from windborne debris. Provide an impact protective system when installing the product in areas that require windborne debris protection.

**Installation:**

**General:** Prepare and install the assembly in accordance with Kawneer's installation instructions and the approved drawing specified in this report. Detailed installation instructions are available from Kawneer.

**Wall Framing Construction:** The window system may be mounted to several types of wall framing construction. The types of wall framing constructions allowed include:

- Concrete (minimum compressive strength: 2,000 psi)
- CMU (concrete filled)
- Wood (minimum specific gravity, SG=0.42)
- Steel (minimum 1/8" thick, Fy=36 ksi)
- Metal stud (minimum 16-gauge, 33 ksi)
- Aluminum (minimum 1/8" thick, 6063-T5)

Refer to the design drawing for specific wall construction requirements.

**Fastener Requirements:**

- Refer to the approved drawing for anchor layout and notes.
- Refer to the approved drawing for the minimum embedment depths for the fasteners and the minimum edge distanced (minimum distance fastener must be from the edge of the substrate material) for the fasteners.

**Installation Instructions:** General installation instructions are specified in document 300990EN, titled "NX-300 Windows Installation Instructions", dated October 2017, published by Kawneer.

**Note:** Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.