

Product Evaluation

WIN2742 | 0724

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-2742

Effective Date: July 1, 2024

Re-evaluation Date: April 2027

Product Name: F110 Vinyl Single Hung Windows, Fin or Frame Installation, Non-Impact Resistant

Manufacturer: NT Window
2900 W. Seminary Dr.
Fort Worth, TX 76133
(800) 969-8830

General Description:

System	Description	Label Rating	Design Pressure Rating
1	F110 Single Hung Windows; O/X	LC-PG25 (54 x 77)-H	+25 / -25 psf
2	F110 Single Hung Windows; O/X	LC-PG50 (48 x 84)-H	+50 / -50 psf
3	F110 Single Hung Windows; O/X	LC-PG50 (48 x 84)-H	+50 / -50 psf
4	F110 Single Hung Windows; O/X	LC-PG60 (48 x 63)-H	+60 / -60 psf

Product Dimensions:

System	Overall Size	Operable Sash Size	Fixed Sash DLO Size
1	54" x 77"	47-1/2" x 35-1/4"	49-1/2" x 35-3/16"

2	48" x 84"	44-3/8" x 41-1/2"	43-9/16" x 41-3/8"
---	-----------	-------------------	--------------------

Product Dimensions (cont.):

System	Overall Size	Operable Sash Size	Fixed Sash DLO Size
3	48" x 84"	44-3/8" x 20-1/2"	43-9/16" x 59-5/8"
4	48" x 63"	44-3/8" x 31.0"	43-9/16" x 28-1/8"

Product Identification (Certification Label on Window):

System		
1-4	Certification Agency	AAMA
	Manufacturer's Name or Code Name	NT-1
	Product Name	F110 SH
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-17

Compliance: The products comply with AAMA/WDMA/CSA 101/I.S.2/A440-17 as referenced in the 2018 IRC and 2018 IBC.

Impact Resistance:

System	Impact Resistant	Requirement
1-4	No	These products have not been tested for windborne debris resistance. An impact protection system is required when installing this product in areas where windborne debris protection is required.

Installation:

System		
1	Type of Installation	Frame
	Wall Framing	Spruce-Pine-Fir dimension lumber
	Fasteners	No. 8 x 2-1/2" pan head screws
	Fastener Location/Spacing	Three per jamb, one 6" in from each end and one at the midspan
1	Type of Installation	Nailing Fin
	Wall Framing	Spruce-Pine-Fir dimension lumber
	Fasteners	No. 6 x 1-1/4" drywall screw
	Fastener Location/Spacing	2" from each corner and nominally 8" on center
2-4	Type of Installation	Frame
	Wall Framing	Spruce-Pine-Fir dimension lumber
	Fasteners	No. 8 x 1-5/8" pan head screws
	Fastener Location/Spacing	3" from each corner and nominally 19" on center at jambs, and 3" on center and one (1) at midspan at head.

Installation (cont.):

System		
2-4	Type of Installation	Nailing Fin
	Wall Framing	Spruce-Pine-Fir dimension lumber
	Fasteners	No. 8 x 2-1/2" pan head screws
	Fastener Location/Spacing	3" from each corner and nominally 12" on center

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.