

Product Evaluation

WIN2751 | 0523

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-2751

Effective Date: May 1, 2023

Re-evaluation Date: April 2027

Product Name: G100 Vinyl Outswing Casement Windows, Fin and Frame Installation, Impact Resistant

Manufacturer: NT Window
2900 W. Seminary Drive
Fort Worth, TX 76133
(800) 969-8830

General Description:

System	Description	Label Rating	Design Pressure Rating
1	G100 Vinyl Outswing Casement Windows; Fin & Frame; X	LC-PG55 (36 x 72)-C Missile Level D	+55 / -55 psf

Product Dimensions:

System	Overall Size	Daylight Opening Size
1	36" x 72"	29-5/8" x 65-5/8"

Product Identification (Certification Label on Window):

System		
1	Certification Agency	AAMA
	Manufacturer's Name or Code Name	NT
	Product Name	G100 Casement
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-17 ASTM E1886-13a/E1996-14a Missile Level D

Impact Resistance:

System	Impact Resistant	Requirement
1	Yes	These products satisfy TDI's criteria for protection from windborne debris. Install the assemblies at a height on the structure that does not exceed the design pressure rating for the assemblies.

Installation:

System		
1	Type of Installation	Fin or Frame Installation
	Wall Framing	Spruce-Pine-Fir dimension lumber
	Fasteners	No. 8 x 2-1/2" washer head wood screws
	Fastener Location/Spacing	3" from each end and 12" o.c. max.
	Fastener Penetration	Minimum of 1-1/2" into the wall framing

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.