

Product Evaluation

WIN629 | 0422

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-629

Effective Date: April 1, 2022

Re-evaluation Date: September 2023

Product Name: Aluminum Clad Wood Direct Set Fixed Windows and Transoms, Fin Installation, Non-Impact Resistant

Manufacturer: Lincoln Wood Products, Inc.
1400 W. Taylor Street
Merrill, WI 54452
(715) 536-2461

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Aluminum Clad Wood Direct Set Fixed Window; O	LC-PG50 (72 x 96)-FW	+50 / -50 psf
2	Aluminum Clad Wood Direct Set Fixed Window; O	CW-PG40 (84 x 120)- FW	+40 / -40 psf
3	Aluminum Clad Wood Direct Set Transom; O	TR-R50 (111 x 29)	+50 / -50 psf

Product Dimensions:

System	Overall Size	Fixed Sash Daylight Opening Size
1	72" x 96"	69-3/4" x 93-3/4"
2	84" x 120"	81-3/4" x 117-3/4"
3	110-1/2" x 29"	107-3/8" x 25-7/8"

Product Identification (Certification Label on Window):

System		
1-2	Certification Agency	AAMA
	Manufacturer's Name or Code Name	LN-1
	Product Name	Clad Direct Set
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08
3	Certification Agency	AAMA
	Manufacturer's Name or Code Name	LN-1
	Product Name	Clad Direct Set Transom
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-05

Impact Resistance:

System	Impact Resistant	Requirement
1-3	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

Installation:

Systems 1-2: The wood wall framing members must be minimum Spruce-Pine-Fir dimension lumber. The window assembly is secured to the wall framing through the nailing fin. The nailing fin is secured to the wall framing with 2" long smooth shank galvanized roofing nails. Locate the nails approximately 7" from each corner and 7" on center along the perimeter. Fasteners must be long enough to penetrate a minimum of 1-1/2" into the wall framing members.

System 3: The wood wall framing members must be minimum Spruce-Pine-Fir dimension lumber. The window assembly is secured to the wall framing through the nailing fin. The nailing fin is secured to the wall framing with 2" long smooth shank galvanized roofing nails. Locate the nails approximately 7" from each corner and 7" on center along the perimeter. In addition, the frame of the window is secured to the wall framing with No. 10 x 3" PFH screws. Locate the screws approximately 15"-18" from each corner and 15"-18" on center along the perimeter. Fasteners must be long enough to penetrate a minimum of 1-1/2" into the wall framing members.

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.