

Product Evaluation

WIN681 | 1021

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-681

Effective Date: October 1, 2021

Re-evaluation Date: March 2025

Product Name: Series 3100 (Model 3102 and 3109) Vinyl Horizontal Sliding Windows, Fin and Frame Installation, Impact Resistant

Manufacturer: Associated Materials, Inc.
3773 State Road
Cuyahoga Falls, OH 44223
(330) 922-5350

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Model 3102 Vinyl Horizontal Sliding Window; OX, XO	R-PG50 (73 x 50)-HS Missile Level D	+50 / -50 psf
2	Model 3102 Vinyl Horizontal Sliding Window; OX, XO	LC-PG40 (73 x 63)-HS Missile Level D	+40 / -40 psf
3	Model 3109 Vinyl Horizontal Sliding Windows; XOX 1/3-1/3-1/3	LC-PG50 (105 x 57)-HS Missile Level D	+50 / -50 psf

Product Dimensions:

System	Overall Size	Operable Sash Size	Fixed Sash Daylight Opening Size
1	73" x 50"	35-7/8" x 46-5/8"	31-5/8" x 44"
2	73" x 63"	35-3/4" x 59-5/8"	32-1/2" x 57-1/8"
3	105" x 57"	Two: 34-5/8" x 53-5/8"	One: 31-7/8" x 51-1/8"

Product Identification (Certification Label on Window):

System		
1	Certification Agency	AAMA
	Manufacturer's Name or Code Name	AMI-05
	Product Name	3102 Impact HS
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA 506; Missile Level D
2	Certification Agency	AAMA
	Manufacturer's Name or Code Name	AMI-05
	Product Name	3102 HS
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA 506; Missile Level D
3	Certification Agency	AAMA
	Manufacturer's Name or Code Name	AMI-05
	Product Name	3109 HS
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA 506; Missile Level D

Impact Resistance:

System	Impact Resistant	Requirement
1-3	Yes	These products satisfy TDI's criteria for protection from windborne debris. Install the assemblies at a height on the structure that does not exceed the design pressure rating for the assemblies.

Installation:

System		
1	Type of Installation	Install in accordance with drawing No. TX-4321 (frame installation) and TX-4322 (fin installation), dated September 10, 2013. Revision 2 dated August 25, 2020. Signed and sealed by Lyndon F. Schmidt, P.E. on April 26, 2021.
	Wall Framing	
	Fasteners	
	Fastener Location/Spacing	
	Fastener Penetration	

Installation:

System		
2	Type of Installation	Install in accordance with drawing No. TX-4321, dated September 10, 2013. Revision 2 dated August 25, 2020. Signed and sealed by Lyndon F. Schmidt, P.E. on April 26, 2021.
	Wall Framing	
	Fasteners	
	Fastener Location/Spacing	
	Fastener Penetration	
3	Type of Installation	Install in accordance with drawing No. TX-5114, dated August 25, 2020. Signed and sealed by Lyndon F. Schmidt, P.E. on April 26, 2021.
	Wall Framing	
	Fasteners	
	Fastener Location/Spacing	
	Fastener Penetration	

Note: Keep the manufacturer’s installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.