

Product Evaluation

DR1065 | 1119

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at 1-800-248-6032.

Evaluation ID: DR-1065

Effective Date: November 1, 2019

Re-evaluation Date: November 2023

Product Name: Series 3700 Vinyl Sliding Doors, Frame Installation, Non-Impact Resistant

Manufacturer: Western Window Systems
2200 East Riverview Drive
Phoenix, AR 85034
(877) 268-1300

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Series 3700 Vinyl Sliding Doors; XXO	LC-PG25 (144 x 96)-SD	+25 / -25 psf

Product Dimensions:

System	Overall Size	Panel Size
1	143.88" x 95.75"	48.75" x 93.68" (3)

Product Identification (Certification Label on Door):

System		
1	Certification agency	AAMA
	Manufacturer's name or code name	WWD-1
	Product name	3700 MULTI SLIDE DOOR
	Test standards	AAMA/WDMA/CSA 101/I.S.2/A440-17

Impact Resistance:

System	Impact Resistant	Requirement
1	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

Installation:

System		
1	Type of installation	Frame Installation
	Wall framing	Southern Yellow Pine dimension lumber
	Fasteners	Minimum No. 10 x 2" PFH screws
	Fastener location/spacing	Approximately 6" from each corner and 12" on center in the center track along the head and side jambs.
	Fastener penetration	Minimum of 1-1/2" into the wall framing

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC, the IBC, and the Texas Revisions.