

Product Evaluation

DR1069 | 0421

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at 800-248-6032.

Evaluation ID: DR-1069

Effective Date: April 1, 2021

Re-evaluation Date: March 2024

Product Name: 8'0" Glazed Fiberglass Inswing Hinged Patio Doors, Doubles w/ Sidelites, Non-Impact Resistant

Manufacturer: Nan Ya Plastics Corporation USA
8989 North Loop East
Houston, TX 77029
(713) 674-7822

General Description:

System	Description	Label Rating	Drawing Number
1	8'0" Glazed Fiberglass Inswing Hinged Patio Doors (OXXO)	R-PG40 (144 x 96)-SHD	08-03411

Component Dimensions:

System	Overall Size	Panel Size	Maximum Daylight Opening Size
1	143-1/4" x 95-3/4"	34-1/2" x 92-1/8"	21" x 79"

Hardware:

System	Component	Quantity	Attachment method
1	Hinges	4	Install hardware in accordance with Nan Ya Plastics USA drawing No. 08-03411, dated April 10, 2019. Revision A dated August 3, 2020. Signed and sealed by Luis R. Lomas, P.E. on February 18, 2021.
	Jam Yuan Enterprises Co., LTD Multi-Point Locking System	1	
	Jam Yuan Enterprises Co., LTD Slab Multi-Point Lock Keeper	1	
	Jam Yuan Enterprises Co., LTD Hook Keeper	1	
	Jam Yuan Enterprises Co., LTD Top/Bottom Bar Keeper	1	
	Jam Yuan Enterprises Co., LTD Top/Bottom Bar System	1	
	Jam Yuan Enterprises Co., LTD Drive Bar Plate	1	

Product Identification (Certification Agency Label on Door):

System		
1	Certification agency	NAMI
	Manufacturer's name or code name	Nan Ya Plastics USA
	Product name	Inswing Glazed Patio Fiberglass Double Door w/ or w/o Sidelites
	Test standards	AAMA/WDMA/CSA 101/I.S.2/A440-08

Impact Resistance:

System	Impact Resistant	Requirement
1	No	Provide an impact protective system when installing the product in areas that require windborne debris.

Acceptance of Smaller Assemblies: Door assemblies with dimensions equal to or smaller than those specified are acceptable with the limitations in this report.

Installation:

System		
1	Type of installation	Install in accordance with Nan Ya Plastics USA drawing No. 08-03411, dated April 10, 2019. Revision A dated August 3, 2020. Signed February 18, 2021.
	Wall framing	
	Fasteners	
	Fastener embedment	
	Fastener location/spacing	

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.