

## Product Evaluation

DR1165 | 0521

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at 800-248-6032.

**Evaluation ID:** DR-1165

**Effective Date:** May 1, 2021

**Re-evaluation Date:** November 2024

**Product Name:** Coastal Performance Vinyl Sliding Glass Doors, Frame Installation, Impact Resistant

**Manufacturer:** Sunrise Windows, LTD.  
200 Enterprise Dr.  
Temperance, MI 48182  
(734) 847-8778

### General Description:

System	Description	Label Rating	Design Pressure Rating
1	Coastal Performance Vinyl Sliding Glass Doors; XO, OX	LC-PG50 (95 x 80)-SD Missile Level D	+50 / -50 psf
2	Coastal Performance Vinyl Sliding Glass Doors; XO, OX	LC-PG50 (96 x 96)-SD Missile Level D	+50 / -50 psf

### Product Dimensions:

System	Overall size	Operable Panel Size	Fixed Panel Daylight Opening Size
1	94-1/2" x 791/2"	47-13/16" x 75-1/4"	40-7/8" x 69-1/16"
2	96" x 96"	48-5/8" x 91-3/4"	41-5/8" x 85-1/2"

**Product Identification (Certification Label on Door):**

System		
1-2	Certification agency	NAMI
	Manufacturer's name or code name	Sunrise Windows & Doors
	Product name	Coastal Performance Impact Vinyl Sliding Glass Door
	Test standards	AAMA/WDMA/CSA 101/I.S.2/A440-17 ASTM E1886-13a/E1996-14a Missile Level D

**Impact Resistance:**

System	Impact Resistant	Requirement
1-2	Yes	These products satisfy TDI's criteria for protection from windborne debris. Install the assemblies at a height on the structure that does not exceed the design pressure rating for the assemblies.

**Installation:**

System		
1-2	Type of installation	Install in accordance with drawings No. TX-5164 and TX-5165, dated March 4, 2021. Signed and sealed by Lyndon F. Schmidt, P.E. on April 6, 2021.
	Wall framing	
	Fasteners	
	Fastener location/spacing	
	Fastener penetration	

**Note:** Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.