

Product Evaluation

DR1166 | 0621

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at 800-248-6032.

Evaluation ID: DR-1166

Effective Date: June 1, 2021

Re-evaluation Date: June 2025

Product Name: Opaque Fiberglass Side Hinged Doors, Inswing and Outswing, Singles and Doubles, with or without Impact Resistant Sidelites, Impact Resistant

Manufacturer: Trinity Glass International
33615 1st Way S
Federal Way, WA 98003
(253) 875-7300

General Description:

System	Description	Label Rating	Drawing Number
1	3'-0" x 8'-0" Single Door; X	+50 / -50 psf Missile Level D	TX-5166
2	3'-0" x 8'-0" Single Door w/ Sidelites & Integral Mullions; OX, XO, OXO (FJ Pine Jambs/Mullions)	Inswing: +40 / -45 psf Outswing: +45 / -45 psf Missile Level D	TX-5166
3	3'-0" x 8'-0" Single Door w/ Sidelites & Integral Mullions; OX, XO, OXO (PVC Jambs/Mullions)	Inswing: +45 / -50 psf Outswing: +45 / -45 psf Missile Level D	TX-5166
4	6'-0" x 8'-0" Double Door; XX	+45 / -45 psf Missile Level D	TX-5167

General Description:

System	Description	Label Rating	Drawing Number
5	6'-0" x 8'-0" Double Door w/ Boxed Sidelites & Combination Mullions; OXXO	+45 / -45 psf Missile Level D	TX-5167
6	6'-0" x 8'-0" Double Door w/ Sidelites & Integral Mullions; OXXO	+45 / -45 psf Missile Level D	TX-5168

Product Dimensions:

System	Maximum Overall Size	Operable Panel Size	Sidelite Panel Daylight Opening Size
1	37-1/2" x 97-3/4"	35-3/4" x 95"	N/A
2-3	OX, XO 52-3/4" x 97-3/4"	35-3/4" x 95"	6-3/4" x 78-3/4"
	OXXO 67-1/2" x 97-3/4"	35-3/4" x 95"	6-3/4" x 78-3/4"
4	74" x 97-3/4"	35-3/4" x 95"	N/A
5	105" x 97-3/4"	35-3/4" x 95"	6-3/4" x 78-3/4"
6	104" x 97-3/4"	35-3/4" x 95"	6-3/4" x 78-3/4"

Components and Hardware:

System	Component	Quantity	Attachment Method
1-6	Hinges	4	Install hardware in accordance with drawings No. TX-5166, TX-5167, and TX-5168, dated March 25, 2021. Signed and sealed by Lyndon F. Schmidt, P.E. on April 7, 2021.
	Knob: Kwikset Signature Series Deadbolt: Kwikset Signature Series (980) OR Knob: Schlage F Series Deadbolt: Schlage B60 Series	1 each	
	Latch and deadbolt strike plates	1 each	
	Astragal strike plate (Systems 4-6)	1	

Product Identification (Manufacturer Label on Door):

System	Manufacturer's name or code name	
1-3	Manufacturer's name or code name	Trinity Glass International
	Product name	Trinity Opaque Fiberglass Side Hinged Doors, Inswing/Outswing, Imp Resistant Door Panels, Singles w/ or w/out Sidelites
	Test standards	ASTM E330-02/E1886-13a/E1996-14a Missile Level D

Product Identification (Manufacturer Label on Door):

System		
4-6	Manufacturer's name or code name	Trinity Glass International
	Product name	Trinity Opaque Fiberglass Side Hinged Doors, Inswing/Outswing, Imp Resistant Door Panels, Doubles w/ or w/out Sidelites
	Test standards	ASTM E330-02/E1886-13a/E1996-14a Missile Level D

Impact Resistance:

System	Impact Resistant	Requirement
1-6	Yes	These products satisfy TDI's criteria for protection from windborne debris. Install the assemblies at a height on the structure that does not exceed the design pressure rating for the assemblies.

Installation:

System		
1-6	Type of installation	Install in accordance with drawings No. TX-5166, TX-5167, and TX-5168, dated March 25, 2021. Signed and sealed by Lyndon F. Schmidt, P.E. on April 7, 2021.
	Wall framing	
	Fasteners	
	Fastener location/spacing	
	Fastener penetration	

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.