

Product Evaluation

DR1186 | 0323

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at 800-248-6032.

Evaluation ID: DR-1186

Effective Date: March 1, 2023

Re-evaluation Date: January 2025

Product Name: 8'-0" Glazed Triple Fiberglass Side Hinged Doors, Inswing and Outswing, Non-Impact Resistant

Manufacturer: GlassCraft Door Company
2002 Brittmoore Rd.
Houston, TX 77043
(713) 690-8282

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Glazed Fiberglass Side Hinged Door with Sidelite; OXXX	Maximum Size Tested: 129 x 98	+50 / -50 psf

Product Dimensions:

System	Overall Size	Operable Panel Size	Panel Daylight Opening Size
1	129" x 98"	36" x 96"	Door: 20-1/2" x 63" Sidelite: 7" x 63"

Components and Hardware:

- **Penrond 5/8" Radius Door hinges:** twelve required; secure with two No. 9 x 3" wood screws through the end holes and two No. 9 x 1" wood screws through the center holes
- **Imperial Series 3-point lockset:** one required
- **Strike plate:** one required; secure with two No. 9 x 3" wood screws
- **Flush Bolts:** four required

Product Identification (Certification Label on Door):

System		
1	Certification agency	NAMI
	Manufacturer's name or code name	Glass Craft Door Company
	Product name	Triple Fiberglass Glazed Inswing & Outswing Door
	Test standards	ASTM E330-02

Impact Resistance:

System	Impact Resistant	Requirement
1	No	Provide an impact protective system when installing the product in areas that require windborne debris.

Installation:

The wood wall framing members must be minimum Spruce-Pine-Fir dimension lumber. The door assembly is secured to the wall framing with minimum No. 9 x 3" wood screws. Along the side jambs, locate the screws approximately 12" from each corner and on center and through the top and bottom mounting holes of the hinges. Along the head and sill, locate the screws approximately 4" from each corner and 12" on center thereafter. Fasteners must be long enough to penetrate a minimum of 1-1/2" into the wall framing members.

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.