

Product Evaluation

DR1218 | 0122

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at 800-248-6032.

Evaluation ID: DR-1218

Effective Date: January 1, 2022

Re-evaluation Date: January 2026

Product Name: Ultimate Prime Wood and Aluminum Clad Wood Outswing French Door Sidelites, Frame Installation, Impact Resistant

Manufacturer: Marvin
P.O. Box 100
Highway 11 West
Warroad, MN 56763
(218) 386-4021

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Ultimate Prime Wood Outswing French Door Sidelites	LC-PG55 (37.44 x 95.5) Missile Level D	+55 / -65 psf
2	Ultimate Clad Wood Outswing French Door Sidelites	LC-PG55 (37.44 x 95.5) Missile Level D	+55 / -65 psf

Product Dimensions:

System	Overall size	Operable Panel Size	Panel Daylight Opening Size
1-2	37-7/16" x 95-1/2"	35-1/16" x 92-1/2"	29-1/16" x 79-5/8"

Product Identification (Certification Label on Door):

System		
1	Certification agency	WDMA
	Manufacturer's name or code name	Marvin
	Product name	UL WD OSW FRDR SL IZ3
	Test standards	AAMA/WMDA/CSA 101/I.S.2/A440-08,11 ASTM E1886-05/E1996-12 Missile Level D
2	Certification agency	WDMA
	Manufacturer's name or code name	Marvin
	Product name	UL OSW FRDR SL IZ3
	Test standards	AAMA/WMDA/CSA 101/I.S.2/A440-08,11 ASTM E1886-05/E1996-12 Missile Level D

Impact Resistance:

System	Impact Resistant	Requirement
1-2	Yes	These products satisfy TDI's criteria for protection from windborne debris. Install the assemblies at a height on the structure that does not exceed the design pressure rating for the assemblies.

Installation (one of the following):

System		
1-2	Type of installation	Frame Installation
	Wall framing	Spruce-Pine-Fir dimension lumber
	Fasteners	No. 8 x 3" screws
	Fastener location/spacing	6" from each corner and 12" on center along the head and side jambs
	Fastener penetration	Minimum of 1-1/2" into the wall framing
1-2	Type of installation	Frame-Bracket Installation (1-9/16" x 6-1/2" x 0.050")
	Wall framing	Spruce-Pine-Fir dimension lumber
	Fasteners	Door Frame: two No. 8 x 5/8" screws Wall Framing: four No. 8 screws
	Fastener location/spacing	6" from each corner and 15" on center along the head and side jambs
	Fastener penetration	Minimum of 1-1/2" into the wall framing

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.