

## Product Evaluation

DR1257 | 0223

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at 800-248-6032.

**Evaluation ID:** DR-1257

**Effective Date:** February 1, 2023

**Re-evaluation Date:** February 2026

**Product Name:** EH Outswing Door, Single or Pairs, Impact Resistant

**Manufacturer:** Edgewater Door  
175 North Western Ave.  
Neenah, WI 54956  
(920)-886-1995

### General Description:

System	Description	Label Rating	Design Pressure Rating
1	Series EH Opaque FRP Outswing Hinged Single Doors; X	MST: 100 x 98 Missile Level D	+70 / -70 psf
2	Series EH Opaque FRP Outswing Hinged Double Doors; XX		

### Product Dimensions:

System	Overall Size	Operable Panel Size	Fixed Panel Daylight Opening Size
1	52" x 98"	47-7/8" x 95-1/2"	N/A
2	100" x 98"	47-7/8" x 95-1/2"	N/A

**Components and Hardware:**

System	Component	Quantity	Attachment Method
1	Mortice Lock: Schlage L9400 Series, Hager 3800 Series, or Sargent 8200 Series	1	Install in accordance with drawing No. EH-DOOR-TDI, dated March 29, 2022. Signed and sealed by Lucas A. Turner, P.E. on October 25, 2022.
	Hinges: Hager BB1279, Ives 5BB1, McKinney TA2714, or Stanley FBB179	4	
2	Mortice Lock: Schlage L9400 Series, Hager 3800 Series, or Sargent 8200 Series	1	
	Hinges: Hager BB1279, Ives 5BB1, McKinney TA2714, or Stanley FBB179	8	
	Surface Bolts: Hager 276D, Ives 453, or Rockwood 580	4	

**Product Identification (Certification Label on Door):**

System		
1-2	Certification agency	NAMI
	Manufacturer's name or code name	Edgewater Door
	Product name	EH Opaque FRP Out-Swing Single or Double Door
	Test standards	ASTM E330-21 ASTM E1886-19/E1996-20 Missile Level D

**Impact Resistance:**

System	Impact Resistant	Requirement
1-2	Yes	These products satisfy TDI's criteria for protection from windborne debris. Install the assemblies at a height on the structure that does not exceed the design pressure rating for the assemblies.

**Installation:**

System		
1-2	Type of installation	Install in accordance with drawing No. EH-DOOR-TDI, dated March 29, 2022. Signed and sealed by Lucas A. Turner, P.E. on October 25, 2022.
	Wall framing	
	Fasteners	
	Fastener location/spacing	
	Fastener penetration	

**Note:** Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.