

PO Box 149104 | Austin, TX 78714 | 1-800-578-4677 | tdi.texas.gov

Product Evaluation

DR429 | 0820

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at 800-248-6032.

Evaluation ID: DR-429 **Effective Date:** August 1, 2020

Re-evaluation Date: August 2024

Product Name: 8'-0" Glazed Fiberglass Side Hinged Doors, Inswing, Singles and Doubles, with or

without Sidelites, Non-Impact Resistant

Manufacturer: Steves and Sons

203 Humble Avenue San Antonio, TX 78225

(210) 924-0470

General Description:

System	Description	Label Rating	Drawing Number
1	3'-0" x 8'-0" Single Door (X)	+40 / -45 psf	TX-4092
2	3'-0" x 8'-0" Single Door (X) +50 / -55 psf *		TX-4092
3	3'-0" x 8'-0" Single Door w/ Sidelite & Combination Reinforced Mullion (1X) (XO, OX)	+40 / -45 psf	TX-4092
4	3'-0" x 8'-0" Single Door w/ Sidelite & Combination Reinforced Mullion (2X) (XO, OX)	+50 / -55 psf **	TX-4092
5	3'-0" x 8'-0" Single Door w/ Sidelites & +40 / Combination Reinforced Mullions (1X) (OXO)		TX-4092
6	3'-0" x 8'-0" Single Door w/ Sidelite & Combination Reinforced Mullion (2X) (OXO)	+50 / -55 psf **	TX-4092

Note: ** Requires security strike and frame corner screws

General Description (Continued):

System	Description	Label Rating	Drawing Number
7	6'-0" x 8'-0" Double Door (XX)	+40 / -45 psf	TX-4093
8	6'-0" x 8'-0" Double Door w/ Sidelites & Combination Reinforced Mullions (OXXO)	+40 / -45 psf	TX-4093

Product Dimensions:

System	Overall Size	Operable Panel Size	Fixed Panel Daylight Opening Size
1-2	37.50" x 98"	35.75" x 95.25"	21" x 79.87"
3-4	54.50" x 98"	35.75" x 95.25"	Door: 21" x 79.87" Sidelite: 7" x 79.87"
5-6	71.50" x 98"	35.75" x 95.25"	Door: 21" x 79.87" Sidelite: 7" x 79.87"
7	74" x 98"	35.75" x 95.25"	21" x 79.87"
8	106.50" x 98"	35.75" x 95.25"	Door: 21" x 79.87" Sidelite: 7" x 79.87"

Components and Hardware:

System	Component	Quantity	Attachment Method
	Hinges	4	
	Lock: Kwikset Series 690 CP	1 each	
	Deadbolt: Kwikset Series 690 CP		wikset Series 690 CP Teach Install in accor
1-8	Latch and Deadbolt standard strike	1 each	drawings No. TX-4092 and TX-4093, dated May 19, 2010. Revision 2 dated
	plate	i eacii	
	Deadbolt security strike plate	1	May 28, 2020, Signed and sealed by
	(Systems 2, 4, 6)	ı	Lyndon F. Schmidt, P.E. on June 1, 2020.
	Astragal strike plate at head and	2	
	sill (Systems 7-8)	2	

Product Identification (Manufacturer Label on Door):

System	,	·
1-6	Certification agency	Self-labeled
	Manufacturer's name	Steves & Sons
		Glazed Fiberglass Side Hinged Doors,
	Product name	Inswing, Non-Impact Resistant Door Panels,
		Singles w/ or w/out Sidelites
	Test standards	ASTM E330-14

Product Identification (Manufacturer Label on Door)-continued:

System		
	Certification agency	Self-labeled
	Manufacturer's name	Steves & Sons
7-8		Glazed Fiberglass Side Hinged Doors,
	Product name	Inswing, Non-Impact Resistant Door Panels,
		Doubles w/ or w/out Sidelites
	Test standards	ASTM E330-14

Impact Resistance:

System	Impact Resistant	Requirement
1-8	No	Provide an impact protective system when installing the
	INO	product in areas that require windborne debris.

Installation:

System		
	Type of installation	
	Wall framing	Install in accordance with Steves & Sons drawings No.
1-8	Fasteners	TX-4092 and TX-4093, dated May 19, 2010. Revision 2 dated May 28, 2020, Signed and sealed by Lyndon F.
	Fastener location/spacing	Schmidt, P.E. on June 1, 2020.
	Fastener penetration	Schmay Fig. 607 July 17 2020.

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.