

PO Box 149104 | Austin, TX 78714 | 1-800-578-4677 | tdi.texas.gov

Product Evaluation

DR430 | 1120

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at 800-248-6032.

Evaluation ID: DR-430

Effective Date: November 1, 2020 **Re-evaluation Date:** November 2024

- **Product Name:** 6'-8" Glazed Steel Side Hinged Doors, Inswing and Outswing, Singles and Doubles, with or without Sidelites, Non-Impact Resistant
- Manufacturer: Steves and Sons 203 Humble Avenue San Antonio, TX 78225 (210) 924-0470

General Description:

System	Description	Label Rating	Drawing Number
1	3'-0" x 6'-8" Single Door; X	+47 / -47 psf	TX-4832
2	3'-0" x 6'-8" Single Door w/ Sidelite & Integral Mullion; OX, XO	+47 / -47 psf	TX-4832
3	3'-0" x 6'-8" Single Door w/ Sidelites & Integral Mullions; OXO	+47 / -47psf	TX-4832
4	6'-0" x 6'-8" Double Door; XX	<u>Columbia Astragal</u> Inswing ONLY: +40 / -40 psf <u>Worldwide Astragal</u> +47 / -47 psf	TX-4833

General Description (continued):

General Description (continued):			
System	Description	Label Rating	Drawing Number
5	6'-0" x 6'-8" Double Door w/ Sidelites & Integral Mullions; OXXO	<u>Columbia Astragal</u> Inswing ONLY: +40 / -40 psf <u>Worldwide Astragal</u> +47 / -47 psf	TX-4833

Product Dimensions:

System	Maximum Overall Size	Operable Panel Size	Maximum Panel Daylight Opening Size
1	37-1/2" x 81-5/8"	35-3/4" x 79-1/4"	Door: 21-1/8" x 63-1/8" Sidelite: N/A
2	53-1/8" x 81-5/8"	35-3/4" x 79-1/4"	Door: 21-1/8" x 63-1/8" Sidelite: 6-1/8" x 63-1/8"
3	68-3/4" x 81-5/8"	35-3/4" x 79-1/4"	Door: 21-1/8" x 63-1/8" Sidelite: 6-1/8" x 63-1/8"
4	74" x 81-5/8"	35-3/4" x 79-1/4"	Door: 21-1/8" x 63-1/8" Sidelite: N/A
5	105" x 81-5/8"	35-3/4" x 79-1/4"	Door: 21-1/8" x 63-1/8" Sidelite: 6-1/8" x 63-1/8"

Components and Hardware:

System	Component	Quantity	Attachment Method
1-5	Hinges Knob: Kwikset (GR. 2) Deadbolt: Kwikset 660 Series (GR. 3) OR Knob: Schlage F Series (GR. 2) Deadbolt: Schlage B60 Series (GR. 1)	3 1 each	Install hardware in accordance with Steves & Sons drawings No. TX-4832 and TX-4833, dated May 9, 2018. Revision 1 dated June 2, 2020. Signed and sealed by Lyndon F. Schmidt, P.E. on June 2, 2020.
	Latch and Deadbolt strike plates	1 each	

Product Identification (Manufacturer Label on Door):

System		
	Manufacturer's name	Steves & Sons
		Glazed Steel Side Hinged Doors,
1-3	Product name	Inswing/Outswing, Non-Impact Resistant Door
		Panels, Singles w/ or w/out Sidelites
	Test standards	ASTM E330-14

System		
	Manufacturer's name	Steves & Sons
4-5		Glazed Steel Side Hinged Doors,
	Product name	Inswing/Outswing, Non-Impact Resistant Door
		Panels, Doubles w/ or w/out Sidelites
	Test standards	ASTM E330-14

Product Identification (Manufacturer Label on Door) - continued:

Impact Resistance:

Sy	/stem	Impact Resistant	Requirement
	1-5	No	Provide an impact protective system when installing the product in areas that require windborne debris.

Acceptance of Smaller Assemblies: Door assemblies with dimensions smaller than those specified are acceptable within the limitations of this report.

Installation:

System			
	Type of installation		
	Wall framing	Install in accordance with Steves & Sons drawings	
1-5	Fasteners	No. TX-4832 and TX-4833, dated May 9, 2018.	
	Fastener location/spacing	Revision 1 dated June 2, 2020. Signed and sealed by Lyndon F. Schmidt, P.E. on June 2, 2020.	
	Fastener penetration	by Lyndon 1. Schmidt, F.L. on June 2, 2020.	

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.