

PO Box 12030 | Austin, TX 78711 | 800-578-4677 | tdi.texas.gov

## **Product Evaluation**

DR584 | 1121

**Engineering Services Program** 

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at 800-248-6032.

**Evaluation ID:** DR-584 **Effective Date:** November 1, 2021

**Re-evaluation Date:** June 2023

Product Name: Models 11i5/11i6/11i8 and Models 51i5/51i6/51i8 Vinyl Sliding Glass Doors, Fin

and Frame Installation, Impact Resistant

Manufacturer: Associated Materials, Inc.

3773 State Road

Cuyahoga Falls, OH 44223

(330) 922-5350

#### **General Description:**

System	Description	Label Rating	Design Pressure Rating
1	Models 11i5/11i6/11i8 Vinyl Sliding Glass Doors; OX	R-PG50 (96 x 80)-SD Missile Level D	+50/ -50 psf
2	Models 51i5/51i6/51i8 Vinyl Sliding Glass Doors; OX	R-PG50 (96 x 80)-SD Missile Level D	+50/ -50 psf

### **Product Dimensions:**

System	Overall size	Operable Panel Size	Fixed Panel Daylight Opening Size
1-2	95-1/2" x 79-1/2"	48-1/2" x 76-3/8"	43-3/4" x 71-5/8"

# **Product Identification (Certification Label on Door):**

System		
	Certification agency	AAMA
1-2	Manufacturer's name or code name	AMI-05
	Product name	11i5/11i6/11i8/51i5/51i6/51i8 SGD
	Test standards AAMA/WDMA/CSA 101/I.S.2/A440	
		AAMA 506; Missile Level D

## **Impact Resistance:**

System	Impact Resistant	Requirement
1-2	Yes	These products satisfy TDI's criteria for protection from windborne debris. Install the assemblies at a height on the structure that does not exceed the design pressure rating for the assemblies.

## **Installation:**

mstanation.	-		
System			
	Type of installation	Install in accordance with drawing No. TX-4202, dated July 25, 2012. Revision 1 dated September 13, 2021. Signed and sealed by Lyndon F. Schmid P.E. on September 14, 2021.	
	Wall framing		
1	Fasteners		
	Fastener location/spacing		
	Fastener penetration	1 .L. on September 14, 2021.	
	Type of installation	Lestellie accordence with discusion No. TV 4202	
	Wall framing	Install in accordance with drawing No. TX-4203,	
2	Fasteners	dated July 25, 2012. Revision 1 dated September 13, 2021. Signed and sealed by Lyndon F. Schmidt,	
	Fastener location/spacing	P.E. on September 14, 2021.	
	Fastener penetration	1 .L. on September 14, 2021.	

**Note:** Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.