

Product Evaluation

DR604 | 0620

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at 800-248-6032.

Evaluation ID: DR-604

Effective Date: June 1, 2020

Re-evaluation Date: June 2024

Product Name: 6'8" Glazed Steel Profiles Series Side Hinged Doors, Inswing and Outswing, Singles and Doubles, with or without Sidelites, Non-Impact Resistant

Manufacturer: Therma-Tru Corporation

118 Industrial Drive
Edgerton, OH 43517
(419) 298-1740

General Description:

System	Description	Label Rating	Drawing Number
1	3'-0" x 6'-8" Single Door (X)	Inswing: +35 / -40 psf Outswing: +40 / -40 psf	TX-4230
2	3'-0" x 6'-8" Single Door w/ Boxed Sidelite & Combination Reinforced Mullion (OX, XO)	Inswing: +35 / -40 psf Outswing: +40 / -40 psf	TX-4230
3	3'-0" x 6'-8" Single Door w/ Boxed Sidelites & Combination Reinforced Mullions (OXO)	Inswing: +35 / -40 psf Outswing: +40 / -40 psf	TX-4230
4	6'-0" x 6'-8" Double Doors (XX)	Inswing: +35 / -40 psf Outswing: +40 / -40 psf	TX-4231
5	6'-0" x 6'-8" Double Doors w/ Boxed Sidelites and Integral Mullions (OXXO)	Inswing: +35 / -40 psf Outswing: +40 / -40 psf	TX-4231

Product Dimensions:

System	Overall Size	Operable Panel Size	Fixed Panel Daylight Opening Size
1	Inswing: 37.75" x 82.12" Outswing: 37.75" x 81.18"	36" x 79.25"	Door: 21.12" x 63.12"
2	Inswing: 54.75" x 82.12" Outswing: 54.75" x 81.18"	36" x 79.25"	Door: 21.12" x 63.12" Sidelite: 6" x 63"
3	Inswing: 71.75" x 81.12" Outswing: 71.75" x 81.18"	36" x 79.25"	Door: 21.12" x 63.12" Sidelite: 6" x 63"
4	Inswing: 74.62" x 82.12" Outswing: 74.62" x 81.18"	36" x 79.25"	Door: 21.12" x 63.12"
5	Inswing: 105.62" x 82.12" Outswing: 105.62" x 81.18"	36" x 79.25"	Door: 21.12" x 63.12" Sidelite: 6" x 63"

Components and Hardware:

System	Component	Quantity	Attachment Method
1-5	Hinges	3	Install hardware in accordance with Therma-Tru drawings No. TX-4230 and TX-4231, dated August 16, 2012. Revision 1 dated April 27, 2020. Signed and sealed by Lyndon F. Schmidt, P.E. on April 27, 2020.
	Knob: Kwikset Signature Series Deadbolt: Kwikset Signature Series (780) OR Knob: Schlage "F" Series (F10) Deadbolt: Schlage "B" Series (B60/62)	1 each	
	Latch and Deadbolt strike plate	1 each	

Product Identification (Manufacturer Label on Door):

System		
1-3	Certification agency	Self-labeled
	Manufacturer's name or code name	Therma-Tru Doors
	Product name	Glazed Steel Side Hinged Doors, Inswing/Outswing, Non-Imp Resistant Door Panels, Singles w/ or w/out Sidelites
	Test standards	ASTM E330-14
4-5	Certification agency	Self-labeled
	Manufacturer's name or code name	Therma-Tru Doors
	Product name	Glazed Steel Side Hinged Doors, Inswing/Outswing, Non-Imp Resistant Door Panels, Doubles w/ or w/out Sidelites
	Test standards	ASTM E330-14

Impact Resistance:

System	Impact Resistant	Requirement
1-5	No	Provide an impact protective system when installing the product in areas that require windborne debris.

Installation:

System		
1-5	Type of installation	Install in accordance with Therma-Tru drawings No. TX-4230 and TX-4231, dated August 16, 2012. Revision 1 dated April 27, 2020. Signed and sealed by Lyndon F. Schmidt, P.E. on April 27, 2020.
	Wall framing	
	Fasteners	
	Fastener location/spacing	
	Fastener penetration	

Note: Keep the manufacturer’s installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.