

PO Box 149104 | Austin, TX 78714 | 1-800-578-4677 | tdi.texas.gov

Product Evaluation

DR610| 0824

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at 800-248-6032.

Evaluation ID: DR-610 **Effective Date:** August 1, 2024

Re-evaluation Date: August 2028

Product Name: 6'8" and 8'0" Therma-Tru Flush Glazed Fiberglass Side Hinged Doors, Inswing

and Outswing, Singles with or without Sidelites, and Doubles, Non-Impact

Resistant

Manufacturer: Endura Products, Inc.

8811 West Market St. Colfax, NC 27235 (336) 668-2472

General Description:

System	Description	Label Rating	Drawing Number
1	3'-0" x 6'-8" Single Door (X)	Inswing: +50 / -55 psf Outswing: +60 / -60 psf	TX-4423
2	3'-0" x 6'-8" Single Door w/ Sidelites (OXO)	Pine Frame Inswing: +50 / -55 psf Outswing: +60 / -60 psf Fusion Frame +50 / -50 psf	TX-4206

General Description:

System	Description	Label Rating	Drawing Number
3	6'-0" x 6'-8" Double Door (XX) Pine Frame	Ultimate Hurricane Astragal Inswing/Outswing: +50 / -55 psf Ultimate Multipoint Astragal Inswing: +45 / -50 psf Outswing: +45 / -45 psf Ultimate Flip Lever Astragal Inswing: +35 / -40 psf Outswing: +35 / -35 psf	TX-4204
4	6'-0" x 6'-8" Double Door (XX) Fusion Frame	Ultimate Hurricane Astragal Inswing/Outswing: +50 / -50 psf Ultimate Multipoint Astragal Inswing: +45 / -50 psf Outswing: +45 / -45 psf Ultimate Flip Lever Astragal Inswing: +35 / -40 psf Outswing: +35 / -35 psf	TX-4204
5	3'-0" x 8'-0" Single Door (X)	Inswing: +40 / -45 psf Outswing: +40 / -40 psf	TX-4424
6	3'-0" x 8'-0" Single Door w/ Sidelites (OXO)	Inswing: +40 / -45 psf Outswing: +40 / -40 psf	TX-4207
7	6'-0" x 8'-0" Double Door (XX)	Ultimate Hurricane Astragal Inswing/Outswing: +40 / -40 psf Ultimate Multipoint Astragal Inswing: +45 / -50 psf Outswing: +45 / -45 psf Ultimate Flip Lever Astragal Inswing: +35 / -40 psf Outswing: +35 / -35 psf	TX-4205

Product Dimensions:

System	Overall Size	Operable Panel Size	Fixed Panel Daylight Opening Size
1	Inswing: 37.75" x 81.94" Outswing: 37.75" x 81.125"	36" x 79.25"	24" x 63"
2	Inswing: 112.94" x 81.94" Outswing: 112.94" x 81.125"	Door/Sidelite: 36" x 79.25"	Door/Sidelite: 24" x 63"
3-4	Inswing: 74.44" x 81.94" Outswing: 74.44" x 81.125"	36" x 79.25"	24" x 63"
5	Inswing: 37.75" x 97.94" Outswing: 37.75" x 97.125"	36" x 95.25"	23.75" x 79"

Product Dimensions (continued):

System	Overall Size	Operable Panel Size	Fixed Panel Daylight Opening Size
6	Inswing: 112.94" x 97.94" Outswing: 112.94" x 97.125"	Door/Sidelite: 36" x 95.25"	Door/Sidelite: 23.75" x 79"
7	Inswing: 74.44" x 97.94" Outswing: 74.44" x 97.125"	36" x 95.25"	23.75" x 79"

Components and Hardware:

System	Component	Quantity	Attachment Method	
1, 5	Hinges	3 (6'8" door) 4 (8'0" door)	Install hardware in accordance with	
	Latch: Kwikset Signature Series (991) Deadbolt: Kwikset Signature Series (980/985)	1 each	Endura drawings No. TX-4423 and TX-4424, dated January 7, 2014, Revision 2 dated November 18, 2019. Signed and sealed by Lyndon F. Schmidt, P.E. on November 18, 2019.	
	Latch and Deadbolt Strike Plate	1 each	Schillidt, F.E. Oli November 10, 2019.	
	Hinges	3 (6'8" door) 4 (8'0" door	Install hardware in accordance with Endura drawings No. TX-4206 and TX-4207, dated August 7, 2012, Revision 3 dated November 18, 2019 Signed and sealed by Lyndon F. Schmidt, P.E. on November 18, 2019	
2, 6	Latch: Kwikset Signature Series (991) Deadbolt: Kwikset Signature Series (980/985)	1 each		
	Latch and Deadbolt Strike Plate	1 each		
3-4, 7	Hinges	3 (6'8" door) 4 (8'0" door	Install hardware in accordance with	
	Latch: Kwikset Signature Series (991) Deadbolt: Kwikset Signature Series (980/985)	1 each	Endura drawings No. TX-4204 and TX-4205, dated August 7, 2012, Revision 4 dated November 18, 2019. Signed and sealed by Lyndon F.	
	Latch and Deadbolt Strike Plate	1 each	Schmidt, P.E. on November 18, 2019.	
•	Astragal Strike Plate	1		

Product Identification (Manufacturer Label on Door):

System		•	
	Certification agency	Self-labeled by manufacturer	
	Manufacturer's name	Endura Products, Inc.	
1-2, 5-6		Flush Glazed Therma-Tru Fiberglass Side Hinged	
	Product name	Doors, Inswing/Outswing, Non-Imp Resistant Door	
		Panels, Single & Single w/ Sidelites	
	Test standards	ASTM E330-14	

Product Identification (Manufacturer Label on Door) - continued:

System			
	Certification agency	Self-labeled by manufacturer	
	Manufacturer's name	Endura Products, Inc.	
3-4, 7		Flush Glazed Therma-Tru Fiberglass Side Hinged	
	Product name	Doors, Inswing/Outswing, Non-Imp Resistant Door	
		Panels, Double	
	Test standards	ASTM E330-14	

Impact Resistance:

System	Impact Resistant	Requirement
1-7	No	Provide an impact protective system when installing the product in areas that require windborne debris.

Installation:

System			
	Type of installation	Install in accordance with Endura drawings No.	
	Wall framing	TX-4423 and TX-4424, dated January 7, 2014,	
1, 5	Fasteners	Revision 2 dated November 18, 2019. Signed an	
	Fastener location/spacing	sealed by Lyndon F. Schmidt, P.E. on	
	Fastener penetration	November 18, 2019.	
	Type of installation	Install in accordance with Endura drawings No. TX-4206 and TX-4207, dated August 7, 2012,	
	Wall framing		
2, 6	Fasteners	Revision 3 dated November 18, 2019. Signed and	
	Fastener location/spacing	sealed by Lyndon F. Schmidt, P.E. on	
	Fastener penetration	November 18, 2019	
	Type of installation	Install in accordance with Endura drawings No.	
3-4, 7	Wall framing	TX-4204 and TX-4205, dated August 7, 2012,	
	Fasteners	Revision 4 dated November 18, 2019. Signed and	
	Fastener location/spacing	sealed by Lyndon F. Schmidt, P.E. on	
	Fastener penetration	November 18, 2019.	

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.