

PO Box 149104 | Austin, TX 78714 | 1-800-578-4677 | tdi.texas.gov

Product Evaluation

DR651 | 0720

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at 800-248-6032.

Evaluation ID: DR-651 **Effective Date:** July 1, 2020

Re-evaluation Date: March 2024

Product Name: Series SLPS Fiberglass Sliding Patio Doors with Sidelites, Non-Impact Resistant

Manufacturer: Nan Ya Plastics Corporation USA

8989 North Loop East Houston, TX 77029 (713) 674-7822

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Series SLPS Fiberglass Sliding Patio Doors with Sidelites (OXXO)	LC-PG50 (142 x 96)-SD	+50 / -50 psf

Product Dimensions:

System	Overall Size	Operable Panel Size	Fixed Panel Daylight Opening Size
1	141-1/8" x 95-1/2"	35-3/4" x 92-3/8" (2)	25" x 79"

Product Identification (Certification Label on Door):

System		
	Certification agency	NAMI
	Manufacturer's name or code name	Nan Ya Plastics USA
1	Product name	SLPS Gliding Fiberglass Patio Door w/ or
		w/o Sidelites
	Test standards	AAMA/WDMA/CSA 101/I.S.2/A440-08

Impact Resistance:

System	Impact Resistant	Requirement
1	N∩	Provide an impact protective system when installing the
		product in areas that require windborne debris protection.

Installation:

System		
	Type of installation	la stall in a secondary as with New Ye Diseting duration
	Wall framing	Install in accordance with Nan Ya Plastics drawi
1	Fasteners	No. 08-01556, dated May 14, 2012, Revision A dated December 18, 2019. Signed and sealed by
	Fastener location/spacing	Luis R. Lomas, P.E. on January 13, 2020.
	Fastener penetration	Luis N. Loillas, F.L. Oli Jahuary 13, 2020.

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.