

PO Box 149104 | Austin, TX 78714 | 1-800-578-4677 | tdi.texas.gov

## **Product Evaluation**

DR705 | 0824

**Engineering Services Program** 

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at 800-248-6032.

**Evaluation ID:** DR-705 **Effective Date:** August 1, 2024

**Re-evaluation Date:** August 2028

Product Name: 6'8" and 8'0" Glazed Fiberglass Masonite Entry Doors, Inswing and Outswing,

Non-Impact Resistant

**Manufacturer:** Endura Products, Inc.

8811 West Market Street

Colfax, NC 27235 (336) 668-2472

**General Description:** 

System	Description	Design Pressure Rating	Drawing Number
1	6'-0" x 6'-8" Double Door (XX); Lip Lite Glazed	Pine & Fusion Frame: Inswing: +40 / -45 psf Outswing: +35 / -35 psf	TX-4432
2	6'-0" x 6'-8" Double Door (XX); Flush Glazed	Pine Frame: Inswing: +45 / -45 psf Outswing: +55 / -55 psf Fusion Frame: Inswing: +45 / -45 psf Outswing: +50 / -50 psf	TX-4432
3	6'-0" x 8'-0" Double Door (XX); Lip Lite Glazed	Inswing: +40 / -45 psf Outswing: +35 / -40 psf	TX-4433

**General Description (continued):** 

System	Description	Design Pressure Rating	Drawing Number
4	6'-0" x 8'-0" Double Door (XX); Flush Glazed	Inswing: +40 / -40 psf Outswing: +45 / -45 psf	TX-4433
5	3'-0" x 6'-8" Single Door (X); Lip Lite Glazed	Inswing: +60 / -60 psf Outswing: +50 / -50 psf	TX-4673
6	3'-0" x 6'-8" Single Door w/ Sidelites (OXO); Lip Lite Glazed	Pine Frame: Inswing: +60 / -60 psf Outswing: +50 / -50 psf Fusion Frame: +50 / -50 psf	TX-4674
7	3'-0" x 8'-0" Single Door (X); Lip Lite Glazed	Inswing: +50 / -50 psf Outswing: +40 / -40 psf	TX-4675
8	3'-0" x 8'-0" Single Door w/ Sidelites (OXO); Lip Lite Glazed	Inswing: +50 / -50 psf Outswing: +40 / -40 psf	TX-4676

### **Product Dimensions:**

System	Overall Size	Operable Panel Size	Fixed Panel Daylight Opening Size
1-2	Inswing: 74" x 82" Outswing: 74" x 81.125"	35.75" x 79.25"	21" x 63"
3-4	Inswing: 74" x 98" Outswing: 74" x 97.125"	35.75" x 95.25"	21" x 79"
5	Inswing: 37.50" x 82" Outswing: 37.50" x 81.125"	35.75" x 79.25"	21" x 63"
6	Inswing: 112.25" x 82" Outswing: 112.25" x 81.125"	Door & Sidelite: 35.75" x 79.25"	Door & Sidelite: 21" x 63"
7	Inswing: 37.50" x 98" Outswing: 37.50" x 97.125"	35.75" x 95.25"	21" x 79"
8	Inswing: 112.25" x 98" Outswing: 112.25" x 97.125"	Door & Sidelite: 35.75" x 95.25"	Door & Sidelite: 21" x 79"

# **Components and Hardware:**

System	Component	Quantity	Attachment Method
1-4	Hinges	3 for 6'8" door 4 for 8'0" door	Install in accordance to Endura drawings No. TX-4432 and TX-4433,
	Endura Trilennium 3000 Series Multipoint Lock (3-pt.)	1	dated January 16, 2014; Revision 3 dated October 23, 2019. Signed and
	Astragal Strike Plate	1	sealed by Lyndon F. Schmidt, P.E. on October 24, 2019.

**Components and Hardware (Continued):** 

System	Component	Quantity	Attachment Method
5-8	Hinges	3 for 6'8" door	Install in accordance with Endura
		4 for 8'0" door	drawings No. TX-4673, TX-4474, and
	Endura Trilennium 3000 Series	1	TX-4675, dated November 9, 2016;
	Multipoint Lock (3-pt.)		Revision 1 dated October 23, 2019.
	Multipoint Strike Plate	1	Signed and sealed by Lyndon F.
			Schmidt, P.E. on October 24, 2019.

## **Product Identification (Manufacturer Label on Door):**

System	•	•
	Certification agency	Self-labeled by manufacturer
	Manufacturer's name	Endura Products, Inc.
1, 3	Product name	Lip Lite Insert Glazed Masonite Fiberglass Side Hinged
1, 3		Doors, Inswing/Outswing, Non-Imp Resistant Door
		Panels, Double
	Test standards	ASTM E330-14
	Certification agency	Self-labeled by manufacturer
	Manufacturer's name	Endura Products, Inc.
2, 4	Product name	Flush Glazed Masonite Fiberglass Side Hinged Doors,
۷, ٦		Inswing/Outswing, Non-Imp Resistant Door Panels,
		Double
	Test standards	ASTM E330-14
	Certification agency	Self-labeled by manufacturer
	Manufacturer's name	Endura Products, Inc.
5, 7	Product name	Lip Lite Insert Glazed Masonite Fiberglass Side Hinged
3, 1		Doors, Inswing/Outswing, Non-Imp Resistant Door
		Panels, Single
	Test standards	ASTM E330-14
	Certification agency	Self-labeled by manufacturer
	Manufacturer's name	Endura Products, Inc.
6, 8	Product name	Lip Lite Insert Glazed Masonite Fiberglass Side Hinged
		Doors, Inswing/Outswing, Non-Imp Resistant Door
		Panels, Single w/ Sidelites
	Test standards	ASTM E330-14

## **Impact Resistance:**

System	Impact Resistant	Requirement
1-8	No	Provide an impact protective system when installing the product in areas that require windborne debris.

## **Installation:**

System			
1-4	Type of installation	Install in accordance with Endura drawings No. TX-4432 and TX-4433, dated January 16, 2014; Revision 3 dated October 23, 2019. Signed and sealed by Lyndon F. Schmidt, P.E. on October 24, 2019.	
	Wall framing		
	Fasteners		
	Fastener location/spacing		
	Fastener penetration		
5-8	Type of installation		
	Wall framing	Install in accordance with Endura drawings No. TX-4673, TX-4474, and TX-4675, dated November 9, 201 Revision 1 dated October 23, 2019. Signed and seale	
	Fasteners		
	Fastener location/spacing	by Lyndon F. Schmidt, P.E. on October 24, 2019.	
	Fastener penetration	]	

**Note:** Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.